



C-75



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/EH/WZ/2024/293

Dated: 09/09/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Lalji Foods Located at Ground Floor & First Floor, A2/43, Main Najafgarh Road, Rajouri, Garden, New Delhi-110027, is running at Ground & 1st floor in a building comprised of Basement, Ground + 03 upper floors, was issued fire safety certificate by this department vide letter no. F6/DFS/MS/2021/247 dated 22/09/2021. The premises was re-inspected by the officer concerned of this department on 23-08-2024 in the presence of Sh. Manoj Rajput (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" (Group-D) and valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 conditions printed overleaf.

Issued on 09/09/2024 at New Delhi by.


(Atul Garg)
Director


09/9/2024

Copy to: -

1. The owner/ Occupier, M/s. Lalji Foods Located at A2/43 Rajouri, Garden, New Delhi.
2. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027. dhowestzone@gmail.com
3. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

INSPECTION REPORT

1. Name & address of the building	M/s. Lalji Foods, A2/43, Main Najafgarh Road, Rajouri, Garden, New Delhi.
2. Type of Occupancy	Assembly (Restaurant)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/2021/247 dated 22/09/2021 (For Ground + 1 st Floor)
5. Fire Safety directives letter No	F6/DFS/MS/BP/2013/2308 dated 24/09/2013
6. Date of inspection	23/08/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Manoj Rajput (Manager)
9. Year of Construction	2010 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2024080712378 dated 09/08/2024

The said restaurant is running at Ground & First floor in a Building comprised of Basement + Ground + 03 upper floors (Basement – Storage, Ground & First – Restaurant, Second & Third floor – Empty).

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	24 m	Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	Provided	MR
	• Basements	03	Provided	MR
	b. Width of staircases			
	• Upper Floors	2x1.5mtr & 1x1m	1.53m, 1.62m & 1.03m	MR
	• Basements	2x1.5mtr & 1x1m	2 x 1.60, 1.03m & 80cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	03	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2 x 2m	2 x 2m & 145cm	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	18 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

7/23				
6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main pump	60 m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	60 m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50,000	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

1R
R
?

Provision of Lifts.				
16	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
NA		NA	NA	
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

5/ADU/MN
1/08/2024

Note: - The restaurant management have submitted an undertaking that they will not use 2nd & 3rd floor for restaurant purpose & if it is used, the FSC will be null & void.

The fire protection systems provided in the building were checked & found functional at the time of inspection. Earlier all the shortcomings issued by this department have been complied by the restaurant management.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter no. : F6/DFS/MS/2021/247 dated 22/09/2021 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

~~ADU (W/2)~~
~~[Signature]~~

~~[Signature]~~
27/8/2024

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (Moti Nagar)

S.F.O. M.B.
Date: 1/08/2024

CFO

The compliance of shortcanning letter dated 30/7/2024 may please be checked from inspecting officer.

~~Director~~ 5/9/2024
I agree Pls. confirm
Any more Sir, The shortcanning

Issued vide this dept letter dtd 30.07.2024