

c-22



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**



No. F6/DFS/MS/2024/School/ 875

Dated: 05/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Nalanda Modern Public School (New Building, C-Block) located at Main Road, Sant Nagar, Burari, Delhi-110084, comprised of basement, ground & 03 upper floors only owned/occupied by the Nalanda Modern Public School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 17.08.2024 in the presence of Sh. Devi Prasad Vats (Chairmen) and that the building/premises is fit for occupancy Class "Group B Educational" with effect from 05/09/2024... for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 05/09/2024 ... at New Delhi

(Atul Garg)  
Director  
Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi – 110054.
2. The Principal, Nalanda Modern Public School (New Building, C-Block) located at Main Road, Sant Nagar, Burari, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. Basement shall not be used for any other purpose except as specified in UBBL, subject to permission from concerned local authority.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

4/4  
**INSPECTION REPORT**

1. Name & address of the building : Nalanda Modern Public School (New Building, C-Block) at Main Road, Sant Nagar, Burari, Delhi-110084.
2. Composition of building : New Building, C-Block (Basement, Ground & 03 upper floors only) but school Is running at ground & 03 upper floors only and basement lying vacant.
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 17.08.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Devi Prasad Vats (Chairmen)
10. Year of Construction : 2022
11. Applicant's letter No. : Online E-mail dated 13.08.2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part 4 Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06m	06m	MR
		Directly Accessible	Directly Accessible	MR
		NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02	02	MR
	02	02	MR	
	<b>b. Width of staircases</b>			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.50m each	1.50m each	MR
	1.50m each	1.50m each	MR	
	<b>c. Protection of exits</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	Required	Provided	MR
	NA	NA	NA	
d. No. of continuous staircases to terrace	02	Provided	MR	
e. Width of Corridor	1.50m	2.40m	MR	
f. Door Size	1.20m	Provided	MR	
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
NA		NA	NA	
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	Required	Exhaust fan	MR
		Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• ISI marking</li> </ul>	08nos	10nos	MR
		ABC/CO2	ABC—10	MR
		ISI Marked	Yes	MR



6	<b>First-Aid Hose Reels.</b>				
	• Total numbers on each floor	01 at each floor	Provided	MR	
	• Length of hose reel hose	30m	30m	MR	
	• Nozzle diameter	5mm	5mm	MR	
7	<b>Automatic fire detection and alarming system.</b>				
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	NA	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	NA	NA	NA	
8	<b>MOEFA</b>				
9	<b>Public Address System.</b>				
10	<b>Automatic Sprinkler System.</b>				
	• Basement	Required	Provided	MR	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11	<b>Internal Hydrants</b>				
	• Size of riser/down-comer	NA	Provided	NA	
	• Number of hydrants per floor	NA	Provided	NA	
	• Hose Box	NA	Provided	NA	
12	<b>Yard Hydrants.</b>				
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13	<b>Pumping Arrangements.</b>				
	• Ground Level	➤ Discharge of main Pump	N/A	N/A	N/A
		➤ Head of Main pump	N/A	N/A	N/A
		➤ Number of main pumps	N/A	N/A	N/A
		➤ Jockey Pump out put	N/A	N/A	N/A
		➤ Jockey pump head	N/A	N/A	N/A
		➤ Standby Pump out put	N/A	N/A	N/A
		➤ Standby Pump Head	N/A	N/A	N/A
		➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
		➤ Pump House Access	N/A	N/A	N/A
		• Terrace level	➤ Discharge of pump	900 LPM	900 LPM
	➤ Head of the pump		40m	40m	MR
	➤ Power Supply		Required	Provided	MR
	➤ Auto Starting of pump		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>				
	• Underground tank capacity	NA	NA	NA	
	➤ Draw-off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA	NA	
	➤ Access to tank	NA	NA	NA	
	• Overhead Tank capacity	15,000 LTR	Provided	MR	
15	<b>Exit Signage.</b>				
	Required	Provided	MR		

Q4

Provision of Lifts.					
16	•	Pressurization of Lift Shaft	N/A	N/A	N/A
	•	Pressurization of Lift lobby	N/A	N/A	N/A
	•	Communication In lift Car	N/A	N/A	N/A
	•	Fireman's Grounding Switch	N/A	N/A	N/A
	•	Lift Signage	N/A	N/A	N/A
17		Standby power supply	Required	Provided	MR
Refuge Area.					
18	>	Total Area	N/A	N/A	N/A
	>	Location	N/A	N/A	N/A
Fire Control Room					
19	•	Detector System Panel	N/A	N/A	N/A
	•	Flow Switch Panel	N/A	N/A	N/A
	•	PA System Panel	N/A	N/A	N/A
	•	Batter backup	N/A	N/A	N/A
	•	Building Floor Plans	N/A	N/A	N/A
20		Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/473 dated 30.07.2024.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by NBC Part-IV, it is recommended to grant Fire Safety Certificate

*C.L. Meena*  
19/08/2024

Signature of the Inspecting Officer  
Name:-C.L. Meena  
Designation:- Asst. Div. Officer (RN)

DO (NW)

*K. J.*  
20/08/2024

By C/O (W2)

*[Signature]*  
23/8

CFO *[Signature]*  
27/08/2024

Director *[Signature]*

*[Signature]*

DCFO *[Signature]*  
Dated: 23/08/2024