

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No: F.6/DFS/MS/WZ/School/2024/ 874

Dated: 05/09 /2024

FIRE SAFETY CERTIFICATE


Certified that the Sanatan Dharam Public School located at East Punjabi Bagh, Road No. 10, New Delhi-110026 is comprised of Ground + 2 upper floors owned/ occupied by Sanatan Dharam Public School was issued FSC by this department vide letter No-F6/DFS/MS/MN/School/2021/390 dated 16.06.2021. The premises was re-inspected by the officer concerned of this department on dated 16/08/2024. In the presence of Smt. Manisha Joshi (Principal) and observed that fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirement in accordance with NBC Part- IV/ DOE circular no. 262 to 263 dated 17.01.2005 and that the school building/ premises is fit for occupancy class "Education" (Group B) with effect from.....05/09/2024 for a period of three years subject to compliance of the conditions mentioned below.

Issued on ..05/09/2024 at New Delhi.


(Anil Gang)
Director

Copy to:

1. The Principal, Sanatan Dharam Public School, Located at Road No. 10, East Punjabi Bagh New Delhi-110026.
2. The Director, Directorate of Education Old Secretariat Delhi – 110054.


03/09/2024

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good
2. Working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The basement shall be used strictly as per building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building	Sanatan Dharam Public School, Road No. 10, East Punjabi Bagh, New Delhi-110026.			
2. Type of Occupancy	Educational (Ground + two upper Floors)			
3. Type of Case	Renewal			
4. Details of previous NOC	F6/DFS/MS/MN/School/2021/390 dated 16/06/2021			
5. Fire Safety directives letter No	N/A			
6. Date of inspection	16/08/2024			
7. Name of the Inspecting Officers	Sarabjeet Singh, ADO (MN)			
8. Name and designation of officers from the building side	Smt. Manisha Joshi (Principal)			
9. Year of Construction	1985 & 1992 (As per previous insp. dated - 06/04/2021)			
10. Applicant's letter No.	Letter no. SDPS/10562/2024 dated 27/07/2024			
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	04 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5 mts	1 x 1.40m, 1 x 1.45m, 1 x 1.0m, 1 x 1.10m Provided	MR (old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	1.5m	2.40m Provided	MR
	g. Door Size	1 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	23 Nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5m	Provided	MR

7 Automatic fire detection and alarming system.				
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10 Automatic Sprinkler System.				
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants				
	• Size of riser/down-comer	100mm	Provided	MR
	• Number of hydrants per floor	03	Provided	MR
	• Hose Box	03	Provided	MR
12 Yard Hydrants.				
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13 Pumping Arrangements.				
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450lpm&180lpm	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14 Captive Water Storage for fire fighting.				
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16 Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA

N/23

Refuge Area.			
	➤ Total Area	NA	NA
	➤ Location	NA	NA
19	Fire Control Room		
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Batter backup	NA	NA
	• Building Floor Plans	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. The shortcoming issued by this department vide letter no. F6/DFS/MS/School/WZ/2024/261 dated: 21/05/2024 have been complied.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/MN/School/2021/390 dated: 16/06/2021 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

26/ADO/MN
21/8/2024

~~24/01/2024~~

~~21/8/2024~~

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO(MN)

FO/283-NW
dated 29.08.24

~~22/8~~

~~CFO Singh
30/8/2024
Director 2/9/24~~

Any Mr Sir, F.T is

put up for your kind personal & signature please.

~~Director 2/9/24~~

~~03/09/2024~~