

C-86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Hospital/2024/WZ/ 552

Dated: 10/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Shree Aggarsain International Hospital (Shree Aggarsain North-Welfare Society (Hospital), P.S.P, Sector-22, Rohini, Delhi-85**, comprised of **Three tire Basement, Ground + 09 upper floors** has already been issued FSC by this department vide letter No. **F.6/DFS/MS/Hospital/2021/WZ/382 dated 09.08.202**. The premises was re-inspected by the officer concerned of this department on **07.08.2024** the presence of **Mr. Surender Sharma (Trustee)** and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class "**Institutional Building (Hospital)**" with effect from 10/09/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/09/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. Mr. Dhiraj Malik (Medical Superintendent) Shree Aggarsain International Hospital, P.S.P, Sector-22, Rohini, Delhi-85

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building sanctioning authority may verify and deviation, the fire safety certificate stands null and void.
3. The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provision of Building Bye laws.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

19/17

INSPECTION REPORT

1. Name & address of the building : Shree Aggarsain International Hospital (Shree Aggarsain North-Welfare Society (Hospital), P.S.P, Sector-22, Rohini, Delhi-85.
2. Type of Occupancy : Institutional (Hospital)
3. Composting of building : (03 Basement + Ground + 09 upper floors)
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/Hospital/2021/WZ/382 dated 09.08.2021
6. Fire Safety directives letter No : F.6/MS/DFS/BP/2010/2586 dated 06.09.2010.
7. Date of inspection : 07.08.2024
8. Name of Inspecting Officer : DO (NW) D.B. Mukherjee & ADO Rohini A.K.Sharma
9. Name and designation of officers
From the building side : Mr. Surender Sharma (Trustee)
10. Year of Construction : 2018.
11. Applicant's letter No. : OD No. 4019 dated 10.07.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	9m	Provided	MR
	• Gate width	6m	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	6nos. +01 Ramp	Provided	MR
	• Basements	6nos. +02 Ramp	Provided	MR
	e. Width of staircases			
	• Upper Floor	2m	Provided	MR
	• Basements	2m	Provided	MR
	f. Protection of exits			
	Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No. of continuous staircases to terrace	3nos.	Provided	MR
	e. Width of Corridor	2.4m	Provided	MR
	f. Door Size	2m, 1.35m & 1.20m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	ISI marked	Provided	MR
	• Types		Provided	MR
	• IS marking		Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	6nos.	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR
	• Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR

Dy. Insp.

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	Required	Provided	MR
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150mm	Provided	MR
		6nos.	Provided	MR
		6nos.	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	16nos.	Provided	MR
		16nos.	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	2850lpm	Provided	MR
		105m	Provided	MR
		02	Provided	MR
		180lpm (2nos.)	Provided	MR
		105m	Provided	MR
		2850lpm	Provided	MR
		105m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-NA-	900lpm	MR
		-NA-	40m	MR
		-NA-	Provided	MR
		-NA-	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	2,00,000ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000ltr	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	180 sq m	Provided	MR
		7 th floor	Provided	MR
19.	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

94

N/19

MR
MR
MR
MR

• Battery backup	Required	Provided	MR
• Building Floor Plans	Required	Provided	MR
Special Fire Protection System for Protection of special Risks, if any:	Required	Provided	MR

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/Hospital/2021/WZ/382 dated 09.08.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

[Signature]
28/08/2024

Signature of the Inspecting Officer
Name: - D.B Mukherjee
Designation:- DO/NW

[Signature]
23/8/24

Signature of the Inspecting Officer
Name: - Ajay Kumar Sharma
Designation:- ADO/Rohini

[Signature]
24/08/2024

CFO/127-NW
dated 28/08/2024

[Signature]
28/8

[Signature]
30/8/2024

[Signature]
21/9/24
Director

[Signature]
DO/NW

[Signature]
29/2024

CFO/127-NW
dated 02/09/2024

[Signature]
DO(NW) put up F.T. letter pt.
A20/R

[Signature]
04/09/2024

Fi letter is put up for kind perusal
and signature please.

[Signature]
Director

[Signature]
26/8/24