


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2024/WZ/ 561

Dated: 13/09/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Aakarsh International (Nail Polish) located at Ground Floor, I-94, Sector 3, Bawana Industrial Area, Bawana, Delhi-110039 comprised of Basement, Ground and First floor was issued fire safety certificate vide Letter No. F6/DFS/MS/2021/WZ/Cos/402 dated 18/08/2021 have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 12/08/2024 in the presence of Sh. Manoj Jain and that the building premise is fit for occupancy under "Class Industrial Building Group G-2 (ii)" for Ground Floor only with effect from 13/09/2024.... for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 13/09/2024... at New Delhi by

(Atul Garg)

Director

Ph. 011-23414000

Conditions for the validity of Fire Safety Certificate:

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able at the time of emergency.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

Copy to :-

1. M/s Aakarsh International (Nail Polish) located at Ground Floor, I-94, Sector 3, Bawana Industrial Area, Bawana, Delhi-110039.
2. The Dy. Drugs Controller/ Licensing Authority, Drug Control department, F-17, Karkardooma, Delhi- 110032.

INSPECTION REPORT

1. Name & address of the building : M/s Aakarsh International (Nail Polish) located at I-94, Sec. 3, Bawana Industrial Area, Bawana, Delhi- 110039.
2. Type of Occupancy : Industrial G- 2(ii)
3. Building Comprised of : Basement, Ground and First Floor.
4. Type of Case : Renewal (FSC for Ground floor only)
5. Details of Previous NOC : F6/DFS/MS/2021/WZ/Cos/402 dated 18/08/2021
6. Fire Safety directives letter No : NBC Part- IV
7. Date of inspection : 12/08/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. Manoj Jain
10. Year of Construction : 2012-13
11. Applicant's letter No. : Outdoor Diary No. 4863 dated 05/08/2024

Previously the building was comprised of Basement, Ground plus two upper floors but the management had removed the rooms at second floor and now the building is comprised of Basement, Ground and First floor.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV/ Inspection report dated 14/03/2019	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	9 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	01	NA
	• Basements	NA	01	NA
	b. Width of staircases			
	• Upper Floor	NA	1.20 m	NA
	• Basements	NA	1.20 m	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	01	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2 × 1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	09	10	MR
	• Types	ABC/CO2 Type	ABC/ CO2 Type	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

N-22

	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	Provided	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	10,000 ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

NA			
NA			
	> Total Area	NA	NA
	> Location	NA	NA
19.	Fire Control Room		
	• Detector System Panel	NA	NA
	• Flow Switch Panel	NA	NA
	• PA System Panel	NA	NA
	• Battery backup	NA	NA
	• Building Floor Plans	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2021/WZ/Cos/402 dated 18/08/2021 under Rule 37 of the Delhi Fire Service Rules, 2010.

ADO (B.W.)
13/8/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

Do (RW)
[Signature]
13/08/2024
By CFO (W2)

[Signature]
16/8

CFO/.....320.....
ated.....16/8/2024.....

cfo Please clarify the occupancy of basement and first floor and the area of each floor.

By CFO (W2)
[Signature]

[Signature]
20/8/2024

[Signature]
23/8

Do (RW)
[Signature]
28/08/2024
ADO (RW)

DCFO/ 320
Dated 23/8/2024