



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/H/2024/SZ/ 554

Dated: 11 / 09 / 2024

FIRE SAFETY CERTIFICATE

Certified that the Warehouse namely **Air Cargo Logistic Centre (ACLC-II)** situated at IGI Airport, New Delhi-110037 (for Shristi Cargo Warehouse Pvt. Ltd), comprised of ground floor (Shed) only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/H/2021/SZ/566 dated 17/11/2021. The premise was re-inspected by the officers concerned of this department on 23/08/2024 in the presence of Mr. Amit Chhabra (Facility Manager) & Mr. Kailash Sharma (Warehouse In-charge) and found that said premise/building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class **Group 'H' (Storage)** with effect from 11 / 09 / 2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/09/2024 at New Delhi by


(ATUL GARG)
 DIRECTOR
 DELHI FIRE SERVICE

Copy to: -

1. Sh. Ritesh Yarlagadda (CEO), M/s Shristi Cargo Warehouse Pvt. Ltd, Office Block, Air Cargo Logistics Centre-II, Opp. Gate 6, Cargo Terminal, IGI Airport, New Delhi-110037
2. The C.E.O., DIAL, New Udaan Bhawan, Opp. Terminal-3, IGI Airport, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc. may be got verified from concerned authorities.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT				
1.	Name & address of the building	Warehouse namely Air Cargo Logistic Centre (ACLC-II) at IGI Airport, New Delhi-110037 (for Shristi Cargo Warehouse Pvt. Limited)		
2.	Type of Occupancy	Group-H (Storage Building)		
3.	Building Comprised of	Ground floor (Shed) only		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/H/2021/SZ/566 dated 17/11/2021		
6.	Fire Safety Directives Letter No.	F6/DFS/MS/2018/3614 Dt. 23/08/2018 (C/27)		
7.	Date of inspection	23/08/2024		
8.	Name of Inspecting Officer	DO (SD) and ADO (SJ)		
9.	Name and designation of Officer from building side	Mr. Amit Chhabra (Facility Manager) and Mr. Kailash Sharma (Warehouse In-charge)		
10.	Year of Construction	2018		
11.	Applicant letter No. Form 'J' received through outdoor diary No. 5361 Dt. 16/08/2024			
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	As per plan	6m	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper floors	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	28 x 1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain/Roof Screen/Curtain Board	Required	Provided	MR
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke managements System			
	• Basements	-NA-	-NA-	-NA-
	• Ground / Upper floors	Annex. M	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	ISI marked	80 Nos	MR
	• Types		ABC/CO ₂ /W CO ₂ /Foam	MR
	• ISI marking		Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Hose-reels	16 Nos	MR
	• Length of hose reel hose		30m	MR
	• Nozzle diameter		5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	-NA-	-NA-	-NA-
	• Ground Floor	Required	Provided	MR
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11	Internal Hydrants			
	• Size of riser/down- comer	Required	100mm	MR
	• Number of hydrants per floor	Required	16 Nos	MR
	• Hose Box	Required	16 Nos	MR
12	Yard Hydrants			
	• Total number of hydrants	Required	28 Nos	MR
	• Hose Box	Required	28 Nos	MR
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	2850 LPM	Provided	MR
	➤ Head of main pump	70m	Provided	MR
	➤ Number of main pumps	One	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70m	Provided	MR
	➤ Standby Pump out put	2850 LPM	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 Ltrs	2,00,000 Ltrs	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltrs	10,000 Ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	➤ Pressurization of lift lobby	-NA-	-NA-	-NA-
	➤ Communication in lift Car	-NA-	-NA-	-NA-
	➤ Fireman's Grounding Switch	-NA-	-NA-	-NA-
	➤ Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

19.	Fire control room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	Manual gas flooding / linear heat sensing tubes with CO ₂ cylinder in HT & LT panel		MR

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/H/2021/SZ/566 dated 17/11/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj
Signature of the Inspecting Officer
Name: Manoj Kumar Sharma
Designation: DO (SD)

Santosh Kumar
02/09/24
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

CFO (HQ)

Vijay
6/9/2024
Vijay
6/9/24
ADY/SJ

Sir, FT letter is put up for your sig. pl

Director
m

Santosh Kumar
09/09/24