



**FIRE SAFETY CERTIFICATE**

Certified that the Amar Jyoti Rehabilitation and Research Centre located at Vikas Marg, Karkardooma, Delhi-110092, comprised of Basement (offices & storage), Ground + Three upper floors owned/ occupied by Amar Jyoti Charitable Trust, have complied with the fire prevention and fire safety requirements in accordance with Education Director circular No. F,16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by officer concern of this department on 02.09.2024 in the presence of Sh. Kamal Pandey and that the building/premises is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 13/09/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

OK DELHI FIRE SERVICE  
(4)

**Copy to :-**

1. Dr. Uma Tuli, Amar Jyoti Rehabilitation and Research Centre, Vikas Marg, Karkardooma, Delhi-110092.
2. The Jt. Director (Land & Estate), Directorate of Education, Lucknow Road, Delhi - 54
3. The Director General of Health Services M.O. I/C Nursing Home Cell, GNCT of Delhi, F-17, Karkardooma, Delhi-110032.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. Presently, the Basement is being used for offices & storage purposes.
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

N/28

## INSPECTION REPORT

1	Name & address of the building	Amar Jyoti Rehabilitation and Research Centre, Karkardooma Vikas Marge, Delhi - 110092.		
2	Building is comprised of	Basement, ground plus three upper floors.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal / New for Educational use (u)		
5	Details of previous FSC	F6/DFS/MS/Hospital/2019/NDZ/258 dated 01/02/2019.		
6	Fire safety direction letter no.	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dt. 01/03/2011 (u)		
7	Date of inspection	02/09/2024		
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)		
9	Name of the designation of officer from the building side	Mr. Kamal Pandey		
10	Year of construction	2003		
11	Applicant's letter no	Outdoor dairy no. 8489 dated 09/11/2023		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	D.O.E circular Requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
a	Road width	6.0 mtrs.	15mtrs.	MR
b	Gate width	4.50mtrs	4.50mtrs	MR
c	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits</b>			
A	Number of staircases			
a	Upper floor	01 nos.	01 nos. + 01 Ramp	MR
b	Basement	01 nos.	01 nos. + 01 Ramp	MR
B	Width of staircases			
a	Upper floor	1.5 mtrs	1.1 mtrs. & 1.70 mtrs. (Ramp)	MR
b	Basement	1.5 mtrs	1.1 mtrs. & 1.70 mtrs.(Ramp)	MR
C	Protection of exits			
a	Fire check door	Required	Provided	MR
b	Pressurization	NA	NA	MR
D	No. of continuous staircases to terrace	01 no.	01 no.	MR
E	Width of corridor	NA	NA	NA
F	Door size	1.0mtrs	Provided	MR
3	<b>Compartmentation</b>			
a	Fire check door	Required	Provided	MR
b	Sealing of electrical shafts	Required	Sealed	MR
c	Fire rating of shaft door	Required	Provided	MR
d	Water curtain	NA	NA	NA
e	Fire dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
a	Basement	Required	Natural Ventilated	NA
b	Upper floor	Required	Natural Ventilated	NA

(u)

<b>5.</b>	<b>Fire Extinguisher</b>				
	a	Total numbers	15 nos.	18 nos.	MR
	b	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	c	ISI marking	ISI marked	ISI marked	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>				
	a	Total numbers of each floor	01 no.	01 no.	MR
	b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	c	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system.</b>				
	a	Type of detectors	NA	Provided	NA
	b	Location of main panel	NA	Provided	NA
	c	Location of repeater panel	NA	Provided	NA
	d	Alternate source of power	NA	Provided	NA
	e	Hooters	NA	Provided	NA
<b>8</b>	<b>MOEFA</b>		NA	Provided	NA
<b>9</b>	<b>Public address System.</b>		Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>				
	a	Basement more than 200 sq.m	Required	Provided	MR
	b	Upper floors	NA	NA	NA
	c	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants</b>				
	a	Size of riser	100 mm	100 mm	MR
	b	Number of hydrants per floor	01 nos.	01 nos.	MR
	c	Hose Box	01 nos.	01 nos.	MR
<b>12</b>	<b>Yard Hydrants.</b>				
	a	Total number of hydrants	NA	NA	NA
	b	Hose Box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements.</b>				
	<b>A</b>	<b>Terrace Level</b>			
	a	Discharge of main Pump	NA	1620 LPM	NA
	b	Head of Main Pump	NA	70mtrs	NA
	c	Number of main pumps	NA	01 no.	NA
	d	Jockey pump out put	NA	180 LPM	NA
	e	Jockey pump head	NA	70 mtrs	NA
	f	Standby pump out put	NA	1620 LPM	NA
	g	Standby pump head	NA	Provided	NA
	h	Auto starting /manual stopping	NA	Provided	NA
	i	Pump House Access	NA	NA	NA
	<b>B</b>	<b>Ground Level</b>			
	a	Discharge of pump	900 LPM	900 LPM	MR
	b	Head of the Pump	40 mtrs.	40 mtrs.	MR
	c	Power supply	Required	Provided	MR
	d	Auto Starting of pump	Required	Provided	MR

W

W

<b>14 Captive Water Storage for Fire Fighting.</b>			
a	Underground tank capacity	NA	50000 liters / NA
b	Draw-off connection	NA	Provided / NA
c	Fire service inlet	NA	Provided / NA
d	Access to tank	NA	Provided / NA
e	Overhead Tank capacity	15000 liters	30000 liters / MR
<b>15 Exit Signage.</b>			
		Required	Provided / MR
<b>16 Provision of Lifts.</b>			
a	Pressurization of Lift Shaft	NA	NA / NA
b	Pressurization of Lift lobby	NA	NA / NA
c	Communication in lift car	Required	Provided / MR
d	Firemen's grounding switch	Required	Provided / MR
e	Lift Signage	Required	Provided / MR
<b>17 Standby power supply</b>			
		Required	Provided / MR
<b>18 Refuge Area.</b>			
a	Total area	NA	NA / NA
b	Location	NA	NA / NA
<b>19 Fire Control Room</b>			
a	Detector system panel	NA	NA / NA
b	Flow switch panel	NA	NA / NA
c	PA system panel	NA	NA / NA
d	Battery backup	NA	NA / NA
e	Building Floor Plans	NA	NA / NA
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>			
		NA	NA / NA

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC was issued vide letter no. F6/DFS/MS/Hospital/2016/NDZ/97 dated 14/01/2016 renewal under rule 35 of the Delhi Fire Service rules 2010 for Educational Building occupancy is recommended.

*[Signature]*  
3/9/2024

Signature of the Inspecting Officer  
Name: - Yashwant Singh Meena  
Designation: - ADO (L.N)

DY.CFO/NDZ

*[Handwritten signature]*  
KVP  
04/09/24

C.F.O.  
*[Handwritten signature]*  
5/9/2024

Director  
*[Handwritten signature]*

*[Handwritten signature]*  
ft PS

Six. F.T Letter is put up for sign. Plead  
Director  
*[Handwritten signature]*  
mmw

*[Signature]*  
11/9/2024