



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

e-44
7
भारतीय
अभूत महोत्सव

No. F6/DFS/MS/School/WZ/2024/892

Dated:- 11/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co-Ed. Sr. Sec. School (ID-1617214) Located at Kunwar Singh Nagar, Ranhaula, New Delhi-110041, comprised of 02 Old Blocks - Ground + 01 Upper Floors each & New Block - Ground + 03 Upper Floors & M.P. Hall, owned/occupied by Govt. Co-Ed. Sr. Sec. School (ID-1617214), was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2021/WZ/663 dated 27/08/2021 & F6/DFS/MS/WZ/2021/990 dated 07/12/2021. The said premises was re-inspected by the officer concerned of this department on 03/09/2024 in the presence of Sh. Vijender Kumar (Estate Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01/03/2011/NBC(Part-IV) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 11/09/2024 for a period of three years, in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on ...11/09/2024.. at New Delhi by.

(Atul Garg)
Director

Tel No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Govt. Co-Ed. Sr. Sec. School, Kunwar Singh Nagar, Ranhaula, New Delhi-110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Govt. Co-Ed. Sr. Sec. School located at **Kunwar Singh Nagar, Ranhola, New Delhi-110041**
2. Type of Occupancy : Educational, (02 old blocks – Ground + 01 Upper Floor) & (01 New Block – Ground + 03 Upper Floors & M.P. Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/WZ/663 dated 27/08/2021 & F6/DFS/MS/WZ/2021/990 dated 07/12/2021
5. Fire Safety directives Letter No. : Cr. No. 3298-3398 dated 01/03/2011/NBC(Part-IV)
6. Date of inspection : 03/09/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Vijender Kumar (Estate Manager)
9. Year of Construction : 2013-14
10. Applicant's letter No. : PRIN./KSN/2024-25/940 dated 09/07/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr. No. 3298-3398 Requirement/NBC (Part-IV) as per FSC dated 27/08/2021 & 07/12/2021	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	New Block-02 nos. & Old Block - 01 no.	New Block-02 nos. Old Block-1 st block – 02 nos. 2 nd block – 04 nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	New Block- 1.5 m x 2 Old Block- 1 st block – 1.35 m x 2 2 nd block – 1.45 m x 4	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	New Block-02 Old Block-01 in each block	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	New Block-1.2 m Old Block-1.0 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	35 nos.	60 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm x 2	NA
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs.	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	➤ Total area			
	➤ Location	NA	NA	NA
19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

Note:- Management has constructed a M.P. hall & have provided 06 nos. exit doors 2.04 m x 2 & 1.25 m x 4 & have complied all fire safety measures.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011/NBC(Part-IV), renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2021/WZ/663 dated 27/08/2021 & F6/DFS/MS/WZ/2021/990 dated 07/12/2021 is recommended.

If agree, accordingly DFA is prepared & put up for approval & signature please

~~DCFO (WZ)~~

~~Amith~~
05/09/24
Aman Kumar Lathar
ADO (JWP)

~~Signature~~
9/9

12/11/24

~~CFO~~
6/9/2021

~~Director~~
Signature

Sir, F.T. letter is put-up for your signature pl.

~~Director~~
Signature

~~Amith~~
09/09/24
ADO (JWP)