

C 90

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/2024/GH/364

Dated: 05/09/2024

FIRE SAFETY CERTIFICATE

Certified that the building of M/S Hotel Lucky Inn Located at Ground, 1st, 2nd & 3rd floors Plot No.12A/12, WEA Karol Bagh, New Delhi - 110005, in a building comprised of basement, ground plus three upper floors using basement as (storage), ground floor (reception & 08 guest rooms), first, second & third floor (11 rooms each floor), (Total=41 guest rooms) was issued FSC vide Letter No F6/DFS/MS/GH/SZ/2021/123, dated 03/03/2021. The premises was re inspected by the officer concerned of this department on 29/08/2024 in the presence of Sh. Sanjay Kumar (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Residential" (guest house) at **ground floor (reception & 08 guest rooms), first, second & third floor (11 rooms each floor) (Total=41 guest rooms)** with effect from 05/09/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 05/09/2024 at New Delhi by.

(Apul Garg)
Director

Delhi Fire Service

Copy to:

1. The Joint. Commissioner of Police (Lic), 1st Floor, Licensing Unit, Police Station, Defence Colony, New Delhi.
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi for information w.r.t. the use of the basement.
3. The Manager, M/S Hotel Lucky Inn Located at Ground, 1st, 2nd & 3rd floors Plot No.12A/12, WEA Karol Bagh, New Delhi - 110005.

Condition for the validity of fire safety certificate

1. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement strictly shall be kept vacant as seen during inspection/ use as per BBL.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

N/US
INSPECTION REPORT

1. Name & address of the building: M/S Hotel Lucky Inn Located at Ground, 1st, 2nd & 3rd floors Plot No.12A/12, WEA Karol Bagh, New Delhi - 110005.
2. Type of Occupancy : Lodging or rooming "A-1"
3. Type of Case : Renewal (Running at Ground, 1st, 2nd & 3rd floors in a building comprised of Basement + G+3 UFs)
4. Details of previous NOC : F6/DFS/MS/GH/SZ/2021/123, dated 03/03/2021
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 29/08/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Sanjay Kumar (Manager)
9. Year of Construction : Before 1990
10. Applicant's letter No. : 2024061309357, dated 13/08/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/33, N/34 & N/35 | Provided at site | Remarks |
|------|---|--------------------------|-----------------------------|---------------------|
| 1. | Access of building | | | MR/NMR |
| | • Road width | 6 mtr | Provided | MR |
| | • Gate width | ---- | Direct accessible from road | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 02 | 02 | MR (Being old case) |
| | • Basements | 02 | 02 | MR (Being old case) |
| | b. Width of staircases | | | |
| | • Upper floors | 1.25m | 1.20m & 0.90m | MR (Being old case) |
| | • Basements | 1.25m | 1.11 & 0.90m | MR (Being old case) |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 01 | 02 | MR |
| | e. Width Of Corridor | Old case | 1.05 m | MR |
| | f. Door Size | Old case | 0.80m | MR (Being old case) |
| 3. | Compartmentation | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | NA | Sealed | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |


X/12 2

| | | | | |
|-----|---|--|-----------------------|----|
| 4. | Smoke managements System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | 30 a/c per hour | Exhaust fans | MR |
| | | 12 a/c per hour | Natural ventilation | MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 10 Nos. ABC & CO ₂ Required | Provided | MR |
| | | | CO ₂ & ABC | MR |
| | | | Provided | MR |
| 6. | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 02 | Provided | MR |
| | | 30 mtr | Provided | MR |
| | | 5 MM | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | CO detectors | Provided | MR |
| | | Required | Provided | MR |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling | Required | Provided | MR |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | <ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | 450 lpm | Provided | MR |
| | | 40 mtrs | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |

| Captive water Storage for fire fighting: | | | | |
|--|--|----------|----------|---------------------|
| 14. | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | Provided | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | Old case | 5000 ltr | MR (Being old case) |
| 15. | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/GH/SZ/2021/123, dated 03/03/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved the FSC may be issued.


 Signature of the Inspecting Officer
 Name: Sh. Udaivir Singh
 Designation : ADO (DWK)

