



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2024/ 295

Dated: 10/09/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. Pasta Street India Pvt. Ltd., Located at property No 38, Upper Ground Floor, Road No. 61, Club Road, West Punjabi Bagh, New Delhi-110026, is running at Upper Ground Floor in a building comprised of Basement + Stilt + Upper Ground Floor + 03 Upper Floors. The building/premises was inspected by the officer concerned of this department on 28/08/2024 in the presence of Sh. Manish Kumar and observed that fire prevention and fire safety arrangements provided in the building found in good working condition. the said premises/building have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises/building is fit for occupancy class "Assembly" (Group - D) and valid upto 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on ...10/09/2024.. at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. The owner/occupier, M/s. Pasta Street India Pvt. Ltd., Located at property No 38, Upper Ground Floor, Road No. 61, Club Road, West Punjabi Bagh, New Delhi-110026.
2. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. (addlcp.lic-dl@nic.in)
3. The Dy. Health Officer, MCD, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. (dhowestzone@gmail.com)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall not be used for any other purpose except as specified in BBL.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

75

Name & address of the building		Pasta Street India Pvt. Ltd., Located at Shop/ property No 38, Upper Ground Floor, Road No. 61, Club Road, West Punjabi Bagh, New Delhi-110026.		
2. Type of Occupancy		Assembly (Restaurant/Eating House)		
3. Type of Case		New		
4. Details of previous NOC		Nil		
5. Fire Safety directives letter No		Nil		
6. Date of inspection		28/08/2024		
7. Name of the Inspecting Officers		Sarabjeet Singh ADO (MN)		
8. Name and designation of officers from the building side		Sh. Manish Kumar		
9. Year of Construction		1998 (As per MHA Portal)		
10. Applicant's letter No.		Online Application ID No. 2024081812841 dated 18/08/2024		
* The said restaurant is running at Upper Ground Floor in a building comprised of Basement + Stilt + Upper Ground Floor + 03 upper floors.				
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 m	Provided	MR
	• Gate width	Required	On Road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	2 mts & 1.5 mts	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NR	NR	NR
	g. Door Size	2 mts & 1.5 mts	Provided	MR
3	Compartmentation.			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	05 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

82



M17

75
आफ़ादीक
अभुन महोत्सव

6 First-Aid Hose Reels.				
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7 Automatic fire detection and alarming system.				
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10 Automatic Sprinkler System.				
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13 Pumping Arrangements.				
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	30 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR	
14 Captive Water Storage for fire fighting.				
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

56/ADO/MN
29/8/2024

(Signature)
29/8/2024

(Signature)
29/8/2024

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

Received on
30/8

Check the uploaded plan. No floor is mentioned.
See & put up accordingly.

(Signature)
29/8/2024

3.67-MNA
02/09/24

(Signature)
ADO (MN)

Sir, Floor is mentioned at e-g
resubmitted pl;

(Signature)

(Signature)
3/9

(Signature)
02/9/2024

3.67
2/9/24

(Signature)
3/9/2024

(Signature)
6/9/24

(Signature)
ADO (MN)