

391

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F.6/DFS/MS/School/2024/WZ/901

Dated: 12/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Queen's Convent School** located at **Sector-25, Rohini, Delhi-110085** comprised of **Ground + 03 upper floors** owned/ occupied by **Queen's Convent School** was issued Fire Safety Certificated vide this office letter no. **F.6/DFS/MS/School/2021/WZ/378** dated **17.05.2021**. The premise was re-inspected by the officer concerned of this department on **02.09.2024** in the presence of **Mr. Brij (Care taker)** and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy under **Educational "Group B"** with effect from 12/09/2024 for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/09/2024 at New Delhi


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 110054.
2. The Principal, Queen's Convent School, Sec-25, Rohini, Delhi-110085.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N/33

INSPECTION REPORT

1.	Name & address of the building	Queen's Convent School, Sec-25, Rohini, Delhi-85		
2.	Type of Occupancy	Educational		
3.	Type of Case	Renewal (Ground + 03 upper floors)		
4.	Details of Previous NOC	F.6/DFS/MS/School/2021/WZ/378 dated 17.05.2021		
5.	Fire Safety directives letter No	NBC Part-IV.		
6.	Date of inspection	02.09.2024.		
7.	Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)		
8.	Name and designation of officers From the building side	Sh. Brij (Caretaker)		
9.	Year of Construction	2002		
10.	Applicant's letter No.	Online e-mail dated 14.08.2024.		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Education Cir.17.01.2005	Provided at site	Remarks MR/NMR
1.	Access to building	Accessible	Accessible	MR
	• Road width	Accessible	4.10m	MR (Old case)
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases	02nos.	02nos.	MR
	• Upper Floors	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	e. Width of staircases	1.5m	02nos. provided	MR
	• Upper Floor	-NA-	-NA-	-NA-
	• Basements	-NA-	-NA-	-NA-
	f. Protection of exits	-NA-	-NA-	-NA-
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	02nos.	02nos.	MR
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation	-NA-	-NA-	-NA-
	f) Fire check door	-NA-	-NA-	-NA-
	g) Sealing of electrical shafts	-NA-	-NA-	-NA-
	h) Fire Rating of shaft door	-NA-	-NA-	-NA-
	i) Water Curtain	-NA-	-NA-	-NA-
	j) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System	-NA-	-NA-	-NA-
	c) Basements	-NA-	-NA-	-NA-
	d) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers	-NA-	-NA-	-NA-
	d) Total numbers	15nos.	Provided	MR
	e) Types	ABC/CO2	Provided	MR
	f) IS marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels	-NA-	-NA-	-NA-
	d) Total numbers on each floor	01nos.	Provided	MR
	e) Length of hose reel hose	30mm	Provided	MR

✍ ✍

	f) Nozzle diameter	5m	Provided	MR
7.	Automatic fire detection and alarming system			
	f) Type of detectors	-NA-	-NA-	-NA-
	g) Location of Main Panel	-NA-	-NA-	-NA-
	h) Location of Repeater Panel	-NA-	-NA-	-NA-
	i) Alternate source of power	-NA-	-NA-	-NA-
	j) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA			
		-NA-	-NA-	-NA-
9.	Public Address System			
		-NA-	Provided	-NA-
10.	Automatic Sprinkler System			
	d) Basement	-NA-	-NA-	-NA-
	e) Ground & Upper Floors	-NA-	-NA-	-NA-
	f) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	d) Size of riser/down-comer	-NA-	Provided	-NA-
	e) Number of hydrants per floor	-NA-	Provided	-NA-
	f) Hose Box	-NA-	Provided	-NA-
12.	Yard Hydrants			
	c) Total number of hydrants	-NA-	-NA-	-NA-
	d) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	450lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	10,000ltr	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	f) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	g) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	h) Communication In lift Car	-NA-	-NA-	-NA-
	i) Fireman's Grounding Switch	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Educational, and removal of shortcomings issued vide letter no. 524 dated 16.08.2024, the FSC issued vide letter no. F.6/DFS/MS/School/2021/WZ/378 dated 17.05.2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Ajay Kumar Sharma
31/9/27

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

DO(NW)

[Signature]
03/09/2024

By CRO/WZ

[Signature]
05/9

1/4205/NW
05/09/24

[Signature]
CRO 11/09/2024
6/9/2024

[Signature]
Director 5/9/24

[Signature]

Fr letter is put up for kind perusal and signature please.

[Signature]
Director

[Signature]
10/9/24