

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya located at Gazipur, Delhi-110096, comprised of Ground plus three upper floors owned/occupied by Sarvodaya Kanya Vidyalaya was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/754 dated 16/09/2021. The School building was re-inspected by the officer concerned of this department on 02/09/2024 in presence of Mrs. Seema Yadav (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational Building" ground plus three upper floors (Group - B) with effect from 10/09/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 10/09/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, D - Block, Yamuna Vihar, Delhi - 110053.
2. The Principal, Sarvodaya Kanya Vidyalaya located at Gazipur, Delhi-110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

11/20

INSPECTION REPORT

1	Name & address of the building	Sarvodaya Kanya Vidyalaya located at Gazipur, Delhi-110096.
2	Building is comprised of	Ground plus three upper floors
3	Type of occupancy	Educational Building
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/754 dated 16/09/2021
6	Fire safety directives letter no.	DFS Act. 2007 and Rule 2010
7	Date of inspection	02/09/2024
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
9	Name of the designation of officer from the building side	Mrs. Seema Yadav (Principal)
10	Year of construction	2001
11	Applicant's letter no.	Email dated 19/08/2024

S.No	Minimum standard of fire prevention and fire safety U/R 33		Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:				
A	Road width	06 mtrs.	06 mtrs	MR	
B	Gate width	4.5 mtrs	4.5 mtrs	MR	
C	Width of internal road	N/A	N/A	N/A	
2	Number, Width, Type and Arrangement of Exits:				
A	Number of staircases				
a	Upper floor	02 no	03 nos. ✓	MR	
b	Basement	N/A	N/A	N/A	
B	Width of staircases				
a	Upper floor	1.5 mtrs.	1.5 mtrs each ✓	MR	
b	Basement	N/A	N/A	N/A	
C	Protection of exits				
a	Fire check door	N/A	N/A	N/A	
b	Pressurization	N/A	N/A	N/A	
D	No. of continuous staircases to terrace	02 no.	02 no. ✓	MR	
E	Width of corridor	1.50 mtrs.	1.80 mtrs ✓	MR	
F	Door size	1.0 mtr.	1.2 mtr. ✓	MR	
3	Compartmentation:				
A	Fire check door	NA	NA	NA	
B	Sealing of electrical shafts	N/A	N/A	N/A	
C	Fire rating of shaft door	N/A	N/A	N/A	
D	Water curtain	N/A	N/A	N/A	
E	Fire dampers	N/A	N/A	N/A	
4	Smoke Management System:				
A	Basement	N/A	N/A	N/A	
B	Upper floor	N/A	N/A	N/A	

W

5.	Fire Extinguisher:			MR	
	A	Total numbers	27 nos.	27 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:			MR	
	A	Total numbers of each floor	02 nos.	02 nos.	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:				
			N/A	N/A	N/A
9	Public Address System:				
10	Automatic Sprinkler System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	N/A	N/A	N/A
	B	Number of hydrants per floor	N/A	N/A	N/A
	C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	10,000 liters.	10,000 liters	MR
E	Overhead tank capacity	Required	Provided	MR
15	Exit Signage:			
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate was issued vide letter no. F6/DFS/MS/School/NDZ/2021/754 dated 16/09/2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.
No file is pending with me before disposal of this case.

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

~~DY. CFO/NDZ~~

~~C.F.O.~~

~~Director~~

Sir.

F.T Letter is Aukup for Sign. Please
Directly
6/9/2021

6/9/2021