



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C 43



No F 6 / DFS / MS / 2024 / School / WZ / 886

Dated 10/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Chhotu Ram Public School** located at **Bakhtawarpur, Delhi-110036** comprised of **Three Blocks (Ground Floor, Ground + First Floor & Ground + Two upper floors)** was issued FSC by this department vide letter No F6 /DFS/MS/2021/School/WZ/694 dated 02.09.2021. The premises was re-inspected by the officer concerned of this department on 30.08.2024 in the presence of Sh. H.K. Yadav, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements under Rule 33 of the Delhi Fire Service Rules, 2010 and the building/ premise is fit for occupancy Group B Educational with effect from ...10/09/2024. for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to the compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on10/09/2024 at New Delhi by

(Atul Garg)
Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. The Principal, Chhotu Ram Public School located at Bakhtawarpur, Delhi-110036.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Chhotu Ram Public School, located at Bakhtawarpur, Delhi- 110036.
2. Type of Occupancy : Educational
3. Building Comprised of : 03 Blocks (Ground Floor, Gr. + 1 & Gr. + 2 upper floors)
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/2021/School/WZ/694 dated 02/09/2021
6. Fire Safety directives letter No : DOE circular dated 17/01/2005/ NBC Part- IV
7. Date of inspection : 30/08/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. H.K Yadav (Principal)
10. Year of Construction : 2000
11. Applicant's letter No. : Outdoor Diary No. 5163 dated 12/08/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE/ NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	6 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03	04	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	G+1= 1.50 m G+2= 1.5 m × 2	G+1= 1.5 m & 0.90 m G+2= 1.7 m & 1.8 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	08	17	MR
	• Types	ABC Type	Provided	MR
	• IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hocters' Location	NA	NA	NA

N-24

8.	MOEFA		NA	NA	NA	NA
9.	Public Address System		NA	NA	NA	NA
10.	Automatic Sprinkler System					NA
	• Basement		NA	NA	NA	NA
	• Ground Floor		NA	NA	NA	NA
	• Sprinkler above false ceiling		NA	NA	NA	NA
11.	Internal Hydrants					NA
	• Size of riser/down-comer		NA	NA	NA	NA
	• Number of hydrants per floor		NA	NA	NA	NA
	• Hose Box		NA	NA	NA	NA
12.	Yard Hydrants					NA
	• Total number of hydrants		NA	NA	NA	NA
	• Hose Box		NA	NA	NA	NA
13.	Pumping Arrangements					NA
	• Ground Level		NA	NA	NA	NA
	➤ Discharge of main Pump		NA	NA	NA	NA
	➤ Head of Main pump		NA	NA	NA	NA
	➤ Number of main pumps		NA	NA	NA	NA
	➤ Jockey Pump out put		NA	NA	NA	NA
	➤ Jockey pump head		NA	NA	NA	NA
	➤ Standby Pump out put		NA	NA	NA	NA
	➤ Standby Pump Head		NA	NA	NA	NA
	➤ Auto Starting/Manual Stopping		NA	NA	NA	NA
	➤ Pump House Access		NA	NA	NA	NA
	• Terrace level					MR
	➤ Discharge of pump	450 lpm		Provided		MR
	➤ Head of the pump	40 m		Provided		MR
	➤ Power Supply	NA		NA		NA
	➤ Auto Starting of pump	NA		NA		NA
14.	Captive Water Storage for fire fighting					MR
	• Underground tank capacity	20,000 ltrs		Provided		MR
	➤ Draw-off connection	NA		NA		NA
	➤ Fire service inlet	NA		NA		NA
	➤ Access to tank	NA		NA		NA
	• Overhead Tank capacity	10,000 ltrs		Provided		MR
		Required		Provided		MR
15.	Exit Signage.					
16.	Provision of Lifts.					
	• Pressurization of Lift Shaft	NA		NA		NA
	• Pressurization of Lift lobby	NA		NA		NA
	• Communication In lift Car	NA		NA		NA
	• Fireman's Grounding Switch	NA		NA		NA
	• Lift Signage	NA		NA		NA
17.	Standby power supply	NA		NA		NA
18.	Refuge Area.					
	➤ Total Area	NA		NA		NA
	➤ Location	NA		NA		NA
19.	Fire Control Room					

NA
NA

N-25

	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel are not under the staircase.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Rules, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2021/School/WZ/694 dated 02/09/2021 under Rule 37 of the Delhi Fire Service Rules, 2010.

[Signature]
2/9/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

[Signature]
02/09/2024
[Signature]
24/09/2023

[Signature]
4/8

DCFO/...429-NAW
Dated...04.09.24...

[Signature]
6/9/2024
Director
[Signature]
6/9/20

[Signature] An. FT letter in pursuance to...
[Signature]
6/9/24

Director (DFS) *[Signature]*
[Signature]