

C15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F.6/DFS/MS/School/2024/SZ/ 882

Dated: 10/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Excellent School** located at 100-B, Baba Haridas Nagar, Ekta Vihar, Najafgarh, New Delhi- 110043, building comprised of ground floor plus two upper floors but **school running at ground and first floor only**, rooms of second floor is closed. Earlier Fire Safety Certificate was issued by this department vide letter no. F.6/MS/DFS/06/2297 dated 04.09.2006 (for the name of Arya Public School). The school building inspected by the officer concerned of this department on dated 09.08.2024 in the presence of Sh. Naveen Kumar (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. 262-362 dated 17.01.2005 issued by the Director of Education and that the building/ premises (**ground and first floor only**) is fit for occupancy class "**Educational Building**" w.e.f. 10/09/2024 for a period of three years, subject to compliance of the conditions printed as under.

Issued on 10/09/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Excellent School located at 100-B, Baba Haridas Nagar, Ekta Vihar, Najafgarh, New Delhi- 110043.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the validity of fire safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

- N/1
1. Name & address of the building : Excellent School at 100-B, Baba Haridas Nagar, Ekta Vihar, Najafgarh, Enclave, Nangli Najafgarh Road, New Delhi-110043.
 2. Type of Occupancy : Educational
 3. Building comprised of : Ground plus two upper floors only (school running at ground and first floor only).
 4. Type of Case : Renewal
 5. Details of Previous NOC : F.6/MS/DFS/06/2297 dated 04.09.2006 (for name of Arya Public School)
 6. Fire Safety directives letter No : Director of Education Circular No. 262-362 dated 17.01.2005
 7. Date of inspection : 09.08.2024
 8. Name of Inspecting Officer : A.D.O. R.K. Yadav
 9. Name and designation of officers
From the building side : Sh. Naveen Kumar (Manager)
 10. Year of Construction :
 11. Applicant's letter No. : Office outdoor dairy No. 3092 dated 19.06.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 17.01.2005 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible 06 mtrs 4.5 mtrs N/A	Provided Directly accessible from road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 Nos.	02 Nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.50 & 0.75 m	1.50 & 1.0 m	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Class Room Door Size	1.20 m	1.20 m	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	• Total numbers	06 no's	Provided	MR
	• Types	ABC/CO ₂ type	Provided	MR
	• IS marking	ISI marked	Provided	MR

N/2

6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A
15.	Exit Signage.	N/A	N/A	N/A


✓

16.	Provision of Lifts.	No Lift		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - Earlier, FSC issued vide letter No. F.6/MS/DFS/06/2297 dated 04.09.2006 (for name of Arya Public School) but now school running the name of Excellent School. School building comprised of ground plus two upper floors but school running at ground and first floor only, rooms of second floor is closed (undertaking submitted by school management with closed rooms photograph).

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/MS/DFS/06/2297 dated 04.09.2006 (for name of Arya Public School), renewal in accordance with the Circular No. Circular No. 262-362 dated 17.01.2005, issued by the Director of Education is recommended.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (South West)

- Please confirm year of construction
- Then check the requirement of width of Stairways.


 ADO (JKP)

16/12/2014
 My School building constructed before 2005. Fire NOC was issued to the