



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS; DELHI FIRE SERVICE; NEW DELHI- 110001

C 58



No. F6/DFS/MS/2024/School/ 906

Dated: 17/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Jyoti Model Senior Secondary School** located at **C-18, Acharya Kriplani Road, Adarsh Nagar, Delhi-110033** comprised of **Ground & 02 upper floors** owned/ occupied by **Jyoti Model Senior Secondary School** was issued Fire Safety Certificate vide this office letter no. **F6/DFS/MS/2019/WZ/2231** dated **27.11.2019**. The premise was inspected by the officer concerned of this department on **07.09.2024** in the presence of **Sh. Vikas Gulati (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no **3298-3398** dated **01.03.2011** and the building/ premise is fit for occupancy class "**Group B Educational**" with effect from**17/09/2024** for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on**17/09/2024**..... at New Delhi

(Atul Garg)
Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Jyoti Model Senior Secondary School located at C-18, Acharya Kriplani Road, Adarsh Nagar, Delhi-110033.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Jyoti Model Sr. Sec. School at C-18, Acharya Kriplani Road, Adarsh Nagar, Delhi-110033.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 02 upper floors only
4. Type of Case : Renewal
5. Details of previous NOC : No.F6/DFS/MS/2019/2231 dated 27.11.2019
6. Fire Safety directives letter No : Nil
7. Date of inspection : 07.09.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Vikas Gulati (Principal)
10. Year of Construction : 2011
11. Applicant's letter No. : Online E-mail dated 30.08.2024


	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)/ Inspection dated 29.01.2013	Provided at site	Remarks MR/NMR
1	Access to building	Accessible	Accessible	MR
	• Road width	Accessible	Accessible	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	02	MR
	• Upper Floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.50m	1.26m & 1.23m	MR (being old case)
	• Upper Floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
f. Door Size	01m	01m	MR	
3	Compartmentation.	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.	NA	NA	NA
	• Basements	Required	Natural Ventilated	MR
	• Upper floors			
5	Fire Extinguishers	08nos	14nos	MR
	• Total numbers	ABC/Co2	ABC-14	MR
	• Types	ISI Marked	Yes	MR
	• ISI marking			

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	01	
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the pump	40m	40m	MR
➤ Power Supply	Required	Provided	MR	
➤ Auto Starting of pump	Required	Provided	MR	
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 LTR	10,000 LTR	MR
15	Exit Signage.			
	Required	Provided	MR	
16	Provision of Lifts.			


	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Batter backup Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2024/School/349 dated 21.06.2024.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2019/WZ/2231 dated 27.11.2019.




 09/09/2024
 Signature of the Inspecting Officer
 Name :-C.L. Meena
 Designation:- ADO/RN

D.B. Mukharjee (DO/NW)


09/09/2024


By efo (w2)


10/9

CFO

 10/09/2024
 Director

 10/9/24


ADO/RN

CFO/473
 Dated: 10/9/2024