

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/908

Dated: 17/09/2024

FIRE SAFETY CERTIFICATE

Certified that **Sahoday Sr. Sec. School, C-1 Safdarjung Development Area, New Delhi-110016** comprised of Ground + Two Upper Floors was issued FSC by this department vide letter no. F6/DFS/MS/School/2021/SZ/698 Dated 02-09-2021. The said premise was re-inspected by officer concerned of this department on 10/09/2024 in presence of FR. James Peter Raj (Manager) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No 262-362 dated 17/01/2005 issued by Director of Education, Govt. of NCT of Delhi and the building is fit for occupancy class "**Educational Building Group - B**" with effect from 17/09/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued 17/09/2024 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Principal, Sahoday Sr. Sec. School C-1 Safdarjung Development Area, Delhi 16
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT				
1	Name & Address of the Building	Sahoday Sr. Sec. School C-1 Safdarjung Development Area, New Delhi-110016		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + 02 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/School/2021/SZ/698 Dated 02-09-2021		
6	Fire Safety Directives Letter No	DOE Circular No.262-362 dated 17-01-2005		
7	Date of Inspection	10/09/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	FR. James Peter Raj (Manager)		
10	Year of construction	1976		
11	Applicant letter No.	Email dated 02/09/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	Required	4.5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	04 Nos	Provided 04	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m	1.40m each	MR (old case)
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 No	Provided 02 nos	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1m	Provided	MR
3.	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	25nos Required	30 Nos	MR
	• Types	ABC / CO2	ABC & W.CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	04 nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7.	Automatic fire detection & alarming system.			

N/17

	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
8.	MOEFA	-NA-	Provided	-NA-
9.	Public Address System	-NA-	Provided	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	100 mm	-NA-
		-NA-	02	-NA-
		-NA-	02	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		450 LPM	450LPM&180LPM	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		10,000 Ltr	10,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	Provided	-NA-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. 	-NA-	-NA-	-NA-

N/18

	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.			-NA-
<p>The fire protection systems provided in the building / premises were test checked at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No F6/DFS/MS/School/2021/SZ/698 Dated 02-09-2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly, DFA is put up for approval and signature please.</p>				
<p><i>[Signature]</i> Signature of the Inspecting Officer Name: Sh. Manoj Kumar Sharma Design: DO (South)</p>		<p><i>[Signature]</i> Signature of the Inspecting Officer Name: Sh. Rajesh Kumar Design: ADO (BCP)</p>		

CFO/(HO)

[Signature]
12/9/2024
Director *[Signature]* 12/9/24
[Signature] 12/9/24

As approved, f.t. letter is put up
for your signature pl

[Signature]
12/9/2024

Director *[Signature]*
[Signature]