



No. F6/DFS/MS/2024/ 566

Dated: 18/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the SAMKALP, Jan Kalyan Shiksha Samittee (Regd.) located at Plot No. 02, FC 3 & 4, Phase-I, Dheerpur, Delhi-110009 comprised of Basement, stilt & 04 upper floors owned/ occupied by the SAMKALP, Jan Kalyan Shiksha Samittee (Regd.) was issued FSC by this department vide letter No. F6/DFS/MS/2020//15 dated 09.01.2020 (for educational occupancy). The premise was inspected by the officer concerned of this department on 10.09.2024 in the presence of Sh. Tarun Awasthi and observed that all the fire prevention and fire safety arrangements as provided in the premise found in good working condition. The premise have therefore deemed complied with the requirements under rule 33 of the Delhi Fire Service Rules, 2010 and the building premise is fit for occupancy class "Mixed Occupancy (Storage, Business, Educational & Residential)" with effect from 18/09/2024.... for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on 18/09/2024..... at New Delhi

(Atul Garg)  
Director  
Ph:-011-23414000

Copy to: -

1. SAMKALP, Jan Kalyan Shiksha Samittee (Regd.) located at Plot No. 02, FC 3 & 3, Phase-I, Dheerpur, Delhi-110009.
2. The Joint Director (L & I) Building, DDA, Building Sadan, INA, New Delhi.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned building sanctioning authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. Basement shall not be used for any other purpose except as specified in UBBL, subject to permission from concerned local authority.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : SAMKALP, Jan Kalyan Shiksha Samittee, Plot no 02, FC 3 &4, Phase-1, Dheerpur, Delhi-110009.
2. Type of Occupancy : Mixed Occupancy (Storage, Business, Educational & Residential)
3. Type of Case : Renewal
4. Composition of building : Basement, Stilt & 04 upper floors, basement-storage, stilt-Reception, 1<sup>st</sup> floor- classroom, 2<sup>nd</sup> floor- Residential, 3<sup>rd</sup> floor- Residential + offices & 4<sup>th</sup> floor- 01 store room & rest part is vacant
5. Details of previous NOC : F6/DFS/MS/2020/15 dated 09.01.2020
6. Fire Safety directives letter No : F6/DFS/MS/2009/294 dated 02.02.2009.
7. Date of inspection : 10.09.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Mr. Tarun Awasthi
10. Year of Construction : 2008
11. Applicant's letter No. : Letter No-Nil dated 02.09.2024

S. No	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09m	Provided	MR
	• Gate width	4.5m	06m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02 & 01 ramp	MR
	b. Width of staircases			
	• Upper Floors	1.25m each	1.50m & 1.40m	MR
	• Basements	1.25m each	1.53m, 1.50m & 01 Ramp 2.70m Basement to GF	MR
	c. Protection of exits			
	• Fire check door	Required	Provided in basement	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	1.25m	Provided	MR
	f. Door Size	1.0m	1.0m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			

		N/18		
	• Basements	Required	Exhaust fan	
	• Upper floors	Required	Natural ventilation	
5	<b>Fire Extinguishers</b>			
	• Total numbers	12nos	12nos	MR
	• Types	ABC/Co2	ABC	MR
	• IS marking	Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA
13	<b>Pumping Arrangements.</b>			
	➤ Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA

	<ul style="list-style-type: none"> <li>• Terrace level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	450 LPM	450 LPM	MR
	<ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>	40m	40m	MR
	<ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Overhead Tank capacity</li> </ul>	5,000 LTR	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>➤ Location</li> </ul>	NA	NA	NA
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by NBC Part-IV, the FSC issued vide letter of even no.F6/DFS/MS/2020//15 dated 09.01.2020 renewal under rule 37 of the Delhi Fire Service Rules, 2010

D.B. Mukharjee (DO/N/W)

*[Signature]*  
11/09/2024  
*[Signature]*

*[Signature]*  
Signature of the Inspecting Officer

Name :- C.L. Meena

Designation:- ADO/RN