



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 909

Dated: 17/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Vidyalaya (Rani Durgawati Id: 1924039) located at East Kidwai Nagar, New Delhi-110023, comprised of ground & four upper floors, owned/occupied by Sarvodaya Vidyalaya, has already been issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2021/41 dated 13/01/2021. The school building was re-inspected by the officer concerned of this department on 09/09/2024 in the presence of Dr. Shashi Bhushan Kumar (Principal) & Sh. Manoj Maurya (TGT-Hindi) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in according with rule 33 of DFS Rules, 2010 and that the building/premises is fit for occupancy class "Group-B Educational" with effect from the date of issue of this certificate for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 17/09/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

01/08

Copy to: -

1. Principal, Sarvodaya Vidyalaya (Rani Durgawati), East Kidwai Nagar, New Delhi-110023
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

N-14

INSPECTION REPORT				
1.	Name & address of the building	Sarvodaya Vidyalaya (Rani Durgawati), East Kidwai Nagar, New Delhi-110023 (School ID: 1924039)		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Ground + 04 upper floors (Excluding common two-tier basement under the building)		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/SZ/2021/41 dt. 13/01/2021		
6.	Fire Safety directives Letter No.	F6/DFS/MS/BP/2013/308 dated 08/10/2013		
7.	Date of inspection	09/09/2024		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Dr. Shashi Bhushan Kumar (Principal) Sh. Manoj Maurya (TGT - Hindi)		
10.	Year of Construction	2016		
11.	Applicant's letter No./ Email received from Id. svinal924039@gmail.com dated 24/08/2024			
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	6m	MR
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	6m	6m	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos	3 Nos	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper floors	1.5m (each)	1.5m x 3nos.	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke managements System			
	• Basements	-NA-	-NA-	-NA-
	• Upper floors	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	10 Nos	16 Nos	MR
	• Types	ABC / CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	-NA-	-NA-	-NA-
	• Upper Floor	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	• Size of riser/down- comer	150mm	Provided	MR
	• Number of hydrants per floor	2nos.	Provided	MR
	• Hose Box	2nos.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Staring/Manual stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	As above	MR
14.	Captive water storage for fire-fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw of connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	25,000 ltrs	25,000 ltrs	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	➤ Pressurization of lift lobby	-NA-	-NA-	-NA-
	➤ Communication in lift Car	-NA-	-NA-	-NA-
	➤ Fireman's Grounding Switch	-NA-	-NA-	-NA-
	➤ Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-

19.	Fire control room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of Special Risks, if any;	-NA-	-NA-	-NA-

The fire protection systems provided in the premises were checked, tested at random and found functional at the time of inspection. The shortcomings communicated by this department vide letter No. F.6/DFS/MS/School/2024/SZ/88 Dt. 01/03/2024 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/SZ/2021/41 dated 13/01/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

S. Kumar
10.03.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

M. M. M.
11/9

Cfo *11/9/2024*
Director *11/9/24*
11/9/24

Sir, FT letter is put up for your sig. pl

Director *13/9/24*

S. Kumar
13.03.24