

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2024/368

Dated : 11/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Mahalaxmi Cottage Guest House** located at **2652, Gali No. 8, Chuna Mandi, Pahar Ganj, New Delhi** comprised of Ground floor (Reception + 01 staff rooms), 1st floor to 3rd floor (03 guest rooms at each floor) and 4th floor & above floor not in use as per affidavit dated 23.12.2019 total 09 guest rooms up to third floor only, was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2021/355 dated 03/09/21. Now, the premises was re-inspected by the officer concerned of this department on 03/09/24 in the presence of Mr. Rajan (Manager) and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the guest house premises is fit for occupancy class **Residential, Sub Division-A-1 Ground floor (Reception + 01 staff rooms), 1st floor to 3rd floor (03 guest rooms at each floor) total 09 guest rooms up to third floor only**, and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued11/09/2024.....at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to :-

1. The Commissioner, North MCD, Civic Center, New Delhi : to kindly ensure the occupancy as detailed above and deviation in construction if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. ID No 2024082213026 dated 23.08.24.
3. The Manager, Mahalaxmi Cottage Guest House 2652, Gali No. 8, Chuna Mandi, Pahar Ganj, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. **This FSC is valid for guest house from ground to third floor only.**
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as exits, staircase, etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

1126
INSPECTION REPORT

1. Name & address of the building: Mahalaxmi Cottage Guest House 2652, Gali No. 8, Chuna Mandi, Pahar Ganj, New Delhi.
2. Type of occupancy:- Residential, Sub Division-A-1
Ground + 04 upper floor, total 09 guest rooms
Ground floor (Reception + 01 staff room), 1st floor to 3rd floor (03 guest rooms at each floor) total 09 rooms Only and fourth floor closed.
And an affidavit dated 23.12.19 regarding not to use any floor above third floor is given by owner
3. Type of case:- Renewal
4. Details of previous FSC:- No.F6/DFS/MS/GH/NDZ/2021/355 dated 03/09/21
5. Fire safety directives No.- N/A
6. Date of inspection:- 03/09/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Mr.Ranjan (Manager)
9. Year of construction:- 2007
10. Applicant's letter No:- Online id no.2024082213026 dated 23.08.24.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	N/A	06 mtr. ✓	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	01 No.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	800 mm	1160 mm ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	1.06 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	1) Total numbers	08 Nos.	12 Nos. ✓	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

N/27

	1) Total number of each floor	01	01	/	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.		MR
	3) Nozzle diameter	05 mm	05 mm		MR
7.	Automatic Fire Detection & Alarming System				
	1) Type of detectors Co Type	Required	Provided	/	MR
	2) Location of main panel	at ground floor	Provided	/	MR
	3) Location of repeater panel	N/A	N/A		N/A
	4) Alternate source of power	Required	Provided		MR
	5) Hooter's Location	at each floor	Provided	/	MR
8.	MOEFA	Required	Provided	/	MR
9.	Public Address System	Required	Provided		MR
10.	Automatic Sprinkler System				
	1) Basement	N/A	N/A		N/A
	2) Upper floors	N/A	N/A		N/A
	3) Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				
	1) Size of riser/down-comer	N/A	N/A		N/A
	2) Number of hydrants per floor	N/A	N/A		N/A
	3) Hose box	N/A	N/A		N/A
12.	Yard Hydrants				
	1) Total number of hydrants	N/A	N/A		N/A
	2) Hose box	N/A	N/A		N/A
13.	Pumping Arrangement				
	1) Ground level	N/A	N/A		N/A
	a) Discharge of main pump	N/A	N/A		N/A
	b) Head of main pump	N/A	N/A		N/A
	c) Number of main pump	N/A	N/A		N/A
	d) Jockey pump out put	N/A	N/A		N/A
	e) Jockey pump head	N/A	N/A		N/A
	f) Stand by pump output	N/A	N/A		N/A
	g) Stand by pump head	N/A	N/A		N/A
	h) Auto starting/Manual stopping	N/A	N/A		N/A
	2) Terrace level				
	a) Discharge of pump	180 LPM	180 LPM	/	MR
	b) Head of pump	25 mtr.	25 mtr.	/	MR
	c) Power supply	Required	Provided		MR
	d) Auto starting of pump	Required	Provided		MR
14.	Captive Water Storage for Fire Fighting				
	1) Under ground tank capacity	N/A	N/A		N/A
	a) Draw-off connection	N/A	N/A		N/A
	b) Fire service inlet	N/A	N/A		N/A
	c) Access to tank	N/A	N/A		N/A
	d) Over head tank capacity	2500 ltr.	2500 ltr.	/	MR

N/28

15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided ✓	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2021/355 dated 03/09/21, under rule 35(6) of the Delhi Fire Service rules 2010 for the guest house only, Accordingly, DFA, is prepared and put up for kind perusal and signature please

Signature of the Inspecting Officer



Name: - Ravinder Singh
Designation: - ADO (CC)

Dy. Insp.

[Signature]
4/9/24

Dy. Insp. (AD-2)

R.V.P.
05/09/24

C.F.O.
[Signature]
7/9/24
Director

[Signature]

As approved for...