



No. F6/DFS/MS/School/NDZ/2024/ 916

Dated: 19/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the ASN International School located at Pocket – IV, Mayur Vihar, Delhi - 110091, comprised of ground plus two upper floors owned/occupied by ASN International School was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2021/690 dated 02/09/2021. The School building was re-inspected by the officer concerned of this department on 04/09/2024 in presence of Mr. Rajiv Nayan Luthra (Vice Chairman) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class –B “Educational Building” ground plus two upper floors only with effect from 19/09/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 19/09/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to: -**

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi - 110054.
2. The Vice Chairman, ASN International School located at Pocket – IV, Mayur Vihar, Delhi - 110091.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/11

## INSPECTION REPORT

1	Name & address of the building	ASN International School located at Pocket - IV, Mayur Vihar, Delhi - 110091.		
2	Building is comprised of	Ground plus two upper floors.		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2021/690 dated 02/09/2021		
6	Fire safety directives letter no.	NBC Part-IV		
7	Date of inspection	04/09/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Rajiv Nayan Luthra (Vice Chairman)		
10	Year of construction	1998 & 2010		
11	Applicant's letter no.	Email dated 03/09/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	06 meters.	15 meters ✓	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases			
a	Upper floor	02 nos.	02 nos. ✓	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 meters.	1.50 meters. & 0.90 meter. ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	01 no. ✓	MR
E	Width of corridor	1.50 meters.	1.50 meters ✓	MR
F	Door size	1.0 Meter.	1.0 Meter. ✓	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

(w)

<b>5. Fire Extinguisher:</b>				
A	Total numbers	06 nos.	06 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 meters.	30 meters.	MR
C	Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	Provided	MR
9	Public Address System:	N/A	N/A	N/A
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>				
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

u

✓

N/13

ASN International School located at Pocket - IV, Mayur Vihar, Delhi - 110091


<b>14 Captive Water Storage for Fire Fighting:</b>				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters.	10,000 liters	MR
		Required	Provided	MR
<b>15 Exit Signage:</b>				
<b>16 Provision of Lifts:</b>				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17 Standby Power Supply:</b>				
<b>18 Refuge Area:</b>				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19 Fire Control Room:</b>				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20 Special Fire Protection systems for protection of special Risks, if any:</b>		N/A	N/A	N/A


The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.



Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The NOC / FSC was issued vide letter no. F6/DFS/MS/School/NDZ/2021/690 dated 02/09/2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.  
**No file is pending with me before disposal of this case.**

  
 5/9/2024

Signature of the Inspecting Officer  
 Name Yashwant Singh Meena  
 Designation ADO (L.N)

~~DY. CFO/NDZ~~  
  
 RVP  
 09/09/24

~~C.F.O~~  
  
 10/9/2024  
 Director  
 11/9/24

~~Sir. F.T letter is put up for sign. At~~  
 Director  
  
 18/9/24  
  
 13/9/2024