

c58

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2024/EH/WZ/304

Dated 19/09/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Chill House Restaurant (A unit of Champion Restro Pvt. Ltd.) Shop No.B-309, North Ex-Shopping Mall, Sector-9, Rohini, Delhi-110085 is running at 3rd floor in building comprised of Basement + Ground + 3 upper floors owned/ occupied by M/s Chill House Restaurant was granted NOC by this department vide letter no. F.6/DFS/MS/2021/EH/WZ/226 dated 13.09.2021. The premises was re-inspected by the officers concerned of this department on 10.09.2024 in the presence of Mr. Karan Singh (Manager) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules,2010. Hence the NOC is renewed and premises is fit for occupancy Group D "Assembly" (Eating House) for Shop No. B-309, 3rd floor only with effect from 19/09/2024 for a period of 03 (Three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/09/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to:-

1. MHA Portal ID-2024090213503 dated 02.09.2024.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Fire+Safety+Acts+and+Rules/>
<http://www.delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>

INSPECTION REPORT

1. Name & address of the building	M/s Chill House Restaurant (A unit of Champion Restro Pvt. Ltd.) Shop No.B-309, North Ex-Shopping Mall, Sector-9, Rohini, Delhi-85.
2. Type of Occupancy	Group D Assembly Building (Eating House)
3. Mall NOC	F.6/DFS/MS/2023/WZ/CMT/452 dated 27.09.2023
4. Type of Case	Renewal (Restaurant is running at Shop No. B-309, at 3 rd floor in a Mall)
5. Details of Previous NOC	F.6/DFS/MS/2021/EH/WZ/226 dated 13.09.2021.
6. Fire Safety directives letter No	NA
7. Date of inspection	09.09.2024.
8. Name of Inspecting Officer	A.K. Sharma ADO (Rohini)
9. Name and designation of officers From the building side	Mr. Karan Singh (Manager)
10. Year of Construction	
10. Applicant's letter No.	Online application no. 2024090213503 dated 02.09.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Rule 35(6)	Provided at site	Remarks MR/NMR
1.	Access to building [North Ex Mall issued FSC vide letter No.F.6/DFS/MS/2023/WZ/CMT/452 dated 27.09.2023]			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Restaurant within Mall	As Above	MR
2.	Number, Width, Type & Arrangement of Exits [Provided & Maintained by Mall management]			
	a. Number of staircases	Restaurant within Mall	As Above	NA
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Restaurant within Mall	As Above	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basement 	Restaurant within Mall	As Above	NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Restaurant within Mall	As Above	NA
	d. No. of continuous staircases to terrace	Restaurant within Mall	As Above	NA
	e. Width of Corridor	Restaurant within Mall	As Above	NA
	f. Door Size	2 exit	1.9 & 1.10 mtr	MR(Old case)
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Restaurant within Mall	As Above	NA
4.	Smoke Management System [Provided & Maintained by Mall management]			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 ACPH	NA	NA
		12 ACPH	Natural Ventilated	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	6 No's	6Nos	MR
		ABC/CO ₂ /W.CO ₂	6No's	MR
		ISI marked	Provided	MR
6.	First-Aid Hose Reels [Provided & Maintained by Mall management]			

	• Total numbers on each floor	One (Near to Restaurant)	As Above	MR
	• Length of hose reel hose	30 m	As Above	MR
	• Nozzle diameter	5 mm	As Above	MR
7.	Automatic fire detection and alarming system [Provided & Maintained by Mall management]			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	NA	As Above	NA
	• Location of Repeater Panel	NA	As Above	NA
	• Alternate source of power	NA	As Above	NA
	• Hooters' Location	NA	As Above	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	As Above	NA
10.	Automatic Sprinkler System [Provided & Maintained by Mall management]			
	• Basement	NA	As Above	NA
	• Ground Floor	NA	As Above	NA
	• Sprinkler above false ceiling	NA	As Above	NA
11.	Internal Hydrants [Provided & Maintained by Mall management]			
	• Size of riser/down-comer	100mm	As Above	MR
	• Number of hydrants per floor	One (near to Restaurant)	As Above	MR
	• Hose Box	One (near to Restaurant)	As Above	MR
12.	Yard Hydrants [Provided & Maintained by Mall management]			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements [Provided & Maintained by Mall management]			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	[Provided & Maintained by Mall management]		
	➤ Discharge of pump	NA	As Above	MR
	➤ Head of the pump	NA	As Above	MR
	➤ Power Supply	Required	As Above	MR
	➤ Auto Starting of pump	Required	As Above	MR
14.	Captive Water Storage for firefighting [Provided & Maintained by Mall management]			
	• Underground tank capacity	NA	As Above	NA
	➤ Draw-off connection	NA	As Above	NA
	➤ Fire service inlet	NA	As Above	NA
	➤ Access to tank	NA	As Above	NA
	• Overhead Tank capacity	NA	As Above	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts. [Provided & Maintained by Mall management]			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA

MR
MR
MR

	• Lift Signage			
	Standby power supply	NA		
	Refuge Area. [Provided & Maintained by Mall management]	Required	NA	NA
	➤ Total Area		As Above	MR
	➤ Location	NA	NA	NA
19.	Fire Control Room [Provided & Maintained by Mall management]	NA	NA	NA
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2021/EH/WZ/226 dated 13.09.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay Kumar Sharma
13/09/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO (Rohini)

DO (NW)

Ajay Kumar Sharma
11/09/2024
DY CPO (WZ)

DCFO/...4.00...11/11/24
Dated..12.7.08/24...

Ajay Kumar Sharma
12/9
CFO
13/9/2024
Director
17/9/24
Ajay Kumar Sharma

FT letter is put up for kind
perusal & signature please.

Ajay Kumar Sharma
19/9/24
Director

Ajay Kumar Sharma
13/09/24

Handwritten initials and marks at the bottom right.