



FIRE SAFETY CERTIFICATE

Certified that the Laxmi Public School located at X – 20, Institutional Area, Karkardooma, Delhi – 110092, comprised of Old Block - (G + 3) & New Block - (B + S + G + 3) Interconnected owned/ occupied by Laxmi Educational Society was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2017/NDZ/758 dated 26.05.2017. the school was re-inspected by the officer concerned of this department on 05/09/2024 in the presence of Mrs. Anita Vashist (Principal) and observed that the school have complied with fire prevention & fire safety requirements in accordance with rules 33 of the Delhi Fire Service Rules, 2010 and found that the school building is fit for occupancy class Group B “Educational Building” with effect from 19/09/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 19/09/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. Director of Education, (GNCT of Delhi), Civil Lines, Old Secretariat Delhi - 110054.
2. The Chairman, Laxmi Education Society located at X – 20, Institutional Area, karkardooma, Delhi – 110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Presently, the Basement is being used for storage purposes.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/14

INSPECTION REPORT

1	Name & address of the building	Laxmi Public School located at X - 20, Institutional Area, karkardooma, Delhi - 110092.		
2	Building is comprised of	Old Block - (G + 3) & New Block - (B + S + G + 3) Interconnected		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2017/NDZ/758 dated 26.05.2017		
6	Fire safety directives letter no.	F6/DFS/MS/BP/2014/177 dated 18.06.2014		
7	Date of inspection	05.09.2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Anita Vashist (Principal)		
10	Year of construction	2003 & 2017		
11	Applicant's letter no.	Outdoor Diary no. 5592 dated 23/08/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Directive Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 mtrs.	24 mtrs.	MR
	B Gate width	6.0 mtrs	6.0 mtrs	MR
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	04 nos.	04 nos.	MR
	b Basement	02 nos.	02 nos.	MR
	B Width of staircases			
	a Upper floor	1.50 mtrs.	1.50 mtrs. each	MR
	b Basement	1.50 mtrs.	1.50 mtrs. each	MR
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	N/A	N/A	N/A
	E Width of corridor	1.50 mtrs.	2.0 mtrs.	MR
	F Door size	1.0 mtrs.	1.0 mtrs.	MR
3	Compartmentation:			
	A Fire check door	Required	Provided	MR
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	Required	Provided	MR
	B Upper floor	Required	Ventilation	MR

u

5. Fire Extinguisher:				
A	Total numbers	24 nos.	25 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	02 nos.	02 nos.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8 MOEFA:		N/A	N/A	N/A
9 Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	Required	Provided	MR
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	Provided	MR
B	Number of hydrants per floor	N/A	02 nos.	N/A
C	Hose box	N/A	Provided	MR
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump	900 LPM	900 LPM	MR
B	Head of the pump	40 mtrs	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

@

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	15,000 liters.	15,000 liters.	MR
		Required	Provided ✓	MR
15 Exit Signage:				
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
		Required	Provided	MR
17 Standby Power Supply:				
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/2023/NDZ/10 dated 09/01/2023 by this department have been rectified by the management.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures required as under the rules the FSC issued vide letter No. F6/DFS/MS/School/2017/NDZ/758 dated 26.05.2017 renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended to be renewed.

Signature of the Inspecting Officer
 Name: Yashwant Singh Meena
 Designation: ADO (L.N)

DY.CFO/NDZ

Yashwant Singh Meena
 11/09/24

C.F.O.
 13/09/2024

Director

Yashwant Singh Meena