

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2024/WZ/School/ 913

Dated: 19/09/2024

FIRE SAFETY CERTIFICATE

Certified that the P.K. Model School, Plot No.117 to 119, Kailash Vihar, Kirari, Suleman Nagar, Delhi- 110086, comprised of building ground + 02 upper floors but school running at ground & 1st floor owned/occupied by P.K. Model School has already been issued FSC by this department vide letter No. F.6/DFS/MS/2021/WZ/School/579 dated 03.08.2021. The premises was re-inspected by the officer concerned of this department on 30.08.2024 in the presence of Sh. Praveen (Principal) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with circular issued by Director of Education, GNCT of Delhi vide letter No.262-362 dated 17.01.2005 and found the building/premises is fit for occupancy class Educational (Group-B) with effect from 19/09/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/09/2024 at New Delhi by


 (Atul Garg)
 DIRECTOR
 Ph; 011-23414000

Copy to :-

1. The Principal, P.K. Model School, Plot No.117 to 119, Kailash Vihar, Kirari, Suleman Nagar Delhi- 110086.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054

Conditions for the validity of fire safety certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K'[sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of Rule 37] along with a copy of this Certificate, six months prior to its expiry."
7. If the school floor is used by the school management in future, FSC will be null & void.
http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	P.K. Model School, Plot No.117 to 119, Kailash Vihar, Kirari, Suleman Nagar, Delhi- 110086.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal (Comprised of building Ground + 02 upper floors but school is running at Ground + 01 upper floor)			
4. Details of Previous NOC	F.6/DFS/MS/2021/WZ/School/579 dated 03.08.2021.			
5. Fire Safety directives letter No	Director of Education Cir dated 01.03.2011/NBC Part-IV			
6. Date of inspection	30.08.2024.			
7. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)			
8. Name and designation of officers From the building side	Mr. Parveen Kumar (Principal)			
9. Year of Construction	1994 & 2015			
10. Applicant's letter No.	Online e-mail dated 16.07.2024.			
S. No	Minimum Standards on fire prevention and fire safety U/R 33	DOE Cir. 1.3.11 NBC Part-IV	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	4.5m	MR
	• Width of internal road	-NA-	-NA-	NA-
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	02nos.	Provided	MR
	• Basements	-NA-	-NA-	NA-
	e. Width of staircases			
	• Upper Floor	1.5m	1.3m & 1.12m	MR(Old case)
	• Basements	-NA-	-NA-	NA-
	f. Protection of exits			
	• Fire check door	-NA-	-NA-	NA-
	• Pressurization	-NA-	-NA-	NA-
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	-NA-	-NA-	NA-
3.	Compartmentation			
	• Fire check door	-NA-	-NA-	NA-
	• Sealing of electrical shafts	-NA-	-NA-	NA-
	• Fire Rating of shaft door	-NA-	-NA-	NA-
	• Water Curtain	-NA-	-NA-	NA-
	• Fire Dampers	-NA-	-NA-	NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	NA-
	b) Upper floors	-NA-	-NA-	NA-
5.	Fire Extinguishers			
	• Total numbers	04nos.	Provided	MR
	• Types	ABC/CO2	ABC/CO2	MR
	• IS marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30mm	Provided	MR

Ay

		5m	Provided	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	NA-
	b) Location of Main Panel	-NA-	-NA-	NA-
	c) Location of Repeater Panel	-NA-	-NA-	NA-
	d) Alternate source of power	-NA-	-NA-	NA-
	e) Hooters' Location	-NA-	-NA-	NA-
8.	MOEFA	-NA-	-NA-	NA-
9.	Public Address System	-NA-	-NA-	NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	NA-
	• Ground & Upper Floors	-NA-	-NA-	NA-
	• Sprinkler above false ceiling	-NA-	-NA-	NA-
11.	Internal Hydrants			
	• Size of riser/down-comer	-NA-	-NA-	NA-
	• Number of hydrants per floor	-NA-	-NA-	NA-
	• Hose Box	-NA-	-NA-	NA-
12.	Yard Hydrants			
	• Total number of hydrants	-NA-	-NA-	NA-
	• Hose Box	-NA-	-NA-	NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	NA-
	➤ Discharge of main Pump	-NA-	-NA-	NA-
	➤ Head of Main pump	-NA-	-NA-	NA-
	➤ Number of main pumps	-NA-	-NA-	NA-
	➤ Jockey Pump out put	-NA-	-NA-	NA-
	➤ Jockey pump head	-NA-	-NA-	NA-
	➤ Standby Pump out put	-NA-	-NA-	NA-
	➤ Standby Pump Head	-NA-	-NA-	NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	NA-
	➤ Pump House Access	-NA-	-NA-	NA-
	Terrace level			
	➤ Discharge of pump	225lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	NA-
	➤ Draw-off connection	-NA-	-NA-	NA-
	➤ Fire service inlet	-NA-	-NA-	NA-
	➤ Access to tank	-NA-	-NA-	NA-
	• Overhead Tank capacity	2500ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	-NA-	-NA-	NA-
	• Pressurization of Lift lobby	-NA-	-NA-	NA-
	• Communication In lift Car	-NA-	-NA-	NA-
	• Fireman's Grounding Switch	-NA-	-NA-	NA-

MR	• Lift Signage	-NA-	-NA-	NA-
	Standby power supply	-NA-	-NA-	NA-
VA-4-	Refuge Area.			
	➤ Total Area	-NA-	-NA-	NA-
	➤ Location	-NA-	-NA-	NA-
19.	Fire Control Room			
	• Detector System Panel	-NA-	-NA-	NA-
	• Flow Switch Panel	-NA-	-NA-	NA-
	• PA System Panel	-NA-	-NA-	NA-
	• Battery backup	-NA-	-NA-	NA-
	• Building Floor Plans	-NA-	-NA-	NA-
20.	Special Fire Protection System for Protection of special Risks, if any:			
		-NA-	-NA-	NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/2021/WZ/School/579** dated **03.08.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Use of IInd floor is not mentioned anywhere. An Undertaking is required

[Signature]
02/09/2024

D.B Mukherjee
DO (NW)

[Signature]
13/08/24

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

FOI/LSB... NW...
dated... 05/09/24...

By CFA (WZ) if agreed, we may return the file for undertaking.

CFA
[Signature]
6/9/2024
Dy CFA (WZ)

[Signature]
5/9/24

LSB...
dated... 9/9/24...

[Signature]
9/9/24
DO (NW)
[Signature]
10/09/2024
ADO (R)

Amended DFA is put up for kind perusal and approval per

[Signature]
13/08/24