



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2024/SZ/ 922

Dated: 23/09 /2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Sanskriti School** located at Plot No. 34, 35, 36, Dr. S. Radhakrishnan Marg, Chanakyapuri, New Delhi-110021, comprised of Junior Block: G+02, Senior Block: G+3, Library Block: G+2, Dinning Block: G+2, Auditorium: B+G+2, Annexe Block: B+G+3, Admin Block: Lower GF, Ground & 1<sup>st</sup> Floor, Gymnasium Block= Ground floor only has already been issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/841 dated 11/10/2021. The premise was re-inspected by the officer concerned of this department on 02/09/2024 in the presence of Mr. Dhruvender Singh (Estate Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in according with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" (Group-B) as above with effect from 23/09/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 23/09/2024 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Sanskriti School at Plot No. 34, 35, 36, Dr. S. Radhakrishnan Marg, Chanakyapuri, New Delhi-110021
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. **Basement shall be used strictly in accordance with the Building Bye Laws.**
2. All the means of escape / entry / exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times as seen during inspection. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The foam is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".



## INSPECTION REPORT

1.	Name & address of the building	Sanskriti School, Plot No. 34, 35, 36, Dr. S. Radhakrishnan Marg, Chanakyapuri, New Delhi-110021		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Junior Block: G+02, Senior Block: G+3, Library Block: G+2, Dinning Block: G+2, Auditorium: B+G+2, Annexe Block: B+G+3, Admin Block: Lower GF, Ground & 1 <sup>st</sup> Floor, Gymnasium Block= Ground floor only.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F.6/DFS/MS/School/2021/SZ/841 Dt. 11/10/2021		
6.	Fire Safety Directives Letter No.	F6/DFS/MS/97/917 dated 31/07/1997 and F6/MS/DFS/BP/2001/2472 Dt. 08/11/2001 (Sch), F6/DFS/MS/BP/ 2003/1004/ Dt 12/03/2003 (Audi), F6/DFS/MS/BP/2006/1061 Dated 05/05/2006 & F6/DFS/MS/BP/2013/65 Dt 01/05/2013 (Annexe)		
7.	Date of inspection	02/09/2024		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Dhruvender Singh (Estate Manager)		
10.	Year of Construction	1996, 2006 & 2013 (Annexe Blk), 2005 Audi		
11.	Applicant's letter No. Form J received through outdoor diary No. 5305 Dt 14/08/2024			
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	12m	MR
	• Gate width	5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	Junior Block-03, Senior Blk-03, Lib. Blk-01, Dinning Blk-02, Auditorium-02, Annexe Blk-02, B&G Hostel Blk-2, Adm Blk-2,	Provided	MR Old Case
	• Basements	Annexe Blk-02, Audi Blk-02 Boys & Girls Hostel-02 Nos	Provided	MR Old Case
	b. Width of staircases			
	• Upper floors	1.5m / 1.25m	Jr. Blk-1.5, 1.5 & ramp-1.55, Sr. Blk-1.5, 1.5 & ramp-1.55 Library Blk-1.38m, Dinning Block-1.50, 1.35 & 2.40m, Boys Hostel-1.48, 1.39, Girls Hostel-1.48, 1.50, Audi Blk- GF to FF-2.3, 2.3 & 1.5m, FF to SF-1.9, 1.9 & 1m, Admn block-LGF. to GF-1.5 & 1.4m & GF to FF-1.4m, Annexe Blk-1.4 & 1.15m,	MR Old Case
	• Basements	1.5m / 1.25m	Boys Hostel-1.5 & 1m, Girls Hostel-1.5 & 1m, Audi Block-1.5 & 1.5m, Annexe Blk-1.4m, 1.15m	MR Old Case
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	-NA-	-NA-	-NA-
	d. No of continuous staircase to terrace	2 Nos	Provided	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	1m & 1.50m (Gym)	1m, 1.80m x 3, 1.50m x 1 (Gym) & 1.80m x 4 Audi	MR



3.	Compartmentation			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	30 ACPH	Exhaust fan provided	MR
		-NA-	-NA-	-NA-
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	ISI marked	80 Nos	MR
			ABC & CO <sub>2</sub>	MR
			Provided	MR
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Hose-Reel	BF-04, GF-20, FF-12, SF-12, TF-3, Annexe Blk: 02nos on each floor	MR
			30m	MR
			5mm	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detector</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & heat	Provided	MR
		Ground Floor	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Auditorium</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	100mm	Provided	MR
		Required	BF-04, GF-20, FF-12, SF-12, TF-3, Annexe Blk: 02nos on each floor	MR
		Required	BF-04, GF-20, FF-12, SF-12, TF-3, Annexe Blk: 02nos on each floor	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Tótal number of hydrants</li> <li>Hose Box</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping Arrangements	Common for entire school complex		
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	2250 LPM	Provided	MR
		60m	Provided	MR
		2nos	Provided	MR
		180 LPM	Provided	MR
		60m	Provided	MR
		2250 LPM	Provided	MR
		60m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

SA

MO



14.	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 Ltr	1,00,000 Ltr	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	➤ Pressurization of lift lobby	-NA-	-NA-	-NA-
	➤ Communication in lift Car	-NA-	-NA-	-NA-
	➤ Fireman's Grounding Switch	-NA-	-NA-	-NA-
	➤ Lift Signage	-NA-	-NA-	-NA-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	-NA-	-NA-	-NA-
	➤ Location	-NA-	-NA-	-NA-
19.	Fire control room			
	➤ Detector system panel	-NA-	-NA-	-NA-
	➤ Flow Switch Panel	-NA-	-NA-	-NA-
	➤ PA System Panel	-NA-	-NA-	-NA-
	➤ Battery backup	-NA-	-NA-	-NA-
	➤ Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection Systems for Protection of special Risks, if any;	-NA-	ABC type fire extinguishers provided near electrical panel	-NA-

Note: - Computer lab & library is being run in basement of Annexe block as observed during inspection.

The fire protection systems provided in the premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/School/2021/SZ/841 dated 11/10/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*Santosh Kumar*  
03/09/24  
Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD)

*ment*  
04/9/24

CFO

(i.e. Annexe block)  
Clarify the use of basement as per approved plan as placed on file

DO (SD)

*ment*

6/9/2024