

C-31

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2024/919

Dated: 19/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Building Satbhrwan arya Sr. Sec. Sechool Located at Arya Samaj Road karol bagh New, New Delhi 110005. Comprised of **Ground + One Upper Floor** was issued Fire Safety Certificate by this department vide Letter no. F6/DFS/MS/School/2021/SZ/677 Dated 31/08/2021, The premise was re inspected by the officer concerned of this department on 06/09/2024 in the presence of Ms. Rita Devgon (Teacher) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE GNCT of Delhi Circular no. 3298-3398 dated 1-3-2011 and that the building/ premises is fit for occupancy class "Educational" with effect from 19/09/24 for a period of **three years**, subject to compliance of the condition given below.

Issued on ... 19/09/2024 at New Delhi by.

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Principal, Satbhrwan arya Sr. Sec. Sechool Located at Arya Samaj Road, karol bagh ~~New~~, New Delhi 110005.
2. The, Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/16

INSPECTION REPORT

1. Name & address of the building: Satbhrwan arya Sr. Sec. Sechool Located at Arya Samaj Road, karol bagh New, New Delhi 110005.
2. Type of Occupancy : Educational (Ground +One Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/SZ/677Dated 31/08/21
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 06/09/2024
7. Name of the Inspecting Officer :Udai vir singh, ADO (DWK)
8. Name and designation of Officer
from the building side : Ms. Rita Devgon (Teacher)
9. Year of Construction : 1950
10. Applicant's letter No. : 44/24-25/220 dated 02/09/2024

| |
|----------------------------------|
| No. of Students=1516 |
| No. of class rooms=60 |
| Plot area=19325 M ² |
| Covered area=10018M ² |

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/12 | Provided at site | Remarks MR/NMR |
|------|---|-------------------------|-------------------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtr | Provided | MR |
| | • Gate width | 4.5 mtr | Directly accessible from road | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 03 no | Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5 mtr or less & 0.75m | 145cm, 140cm & 135cm | MR(Old Case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 1 | 02 | MR |
| | e. Width Of Corridor | 1.5 mtr | Provided | MR |
| | f. Door Size | 01 mtr | 1m Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | 12 a/c per hour | Natural Ventilation | MR |

W

10

| | | | | |
|-----|---|-----------------------|-----------------|----|
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 16 Nos. | Provided | MR |
| | | ABC & CO ₂ | ABC | MR |
| | | ISI marked | ISI marked | MR |
| 6. | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | DG set 62.5 KVA | NA |
| | | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | <ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | NA | NA | NA |
| | | NA | NA | NA |
| 13 | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 14. | Captive water Storage for fire fighting: | | | |
| | <ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| | | NA | NA | NA |
| 15 | Exit Signage | Required | Provided | MR |

w/18

| | | | | |
|-----|--|----|----|----|
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter F6/DFS/MS/School/2021/SZ/677 Dated 31/08/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday Vir Singh*
 Designation *AO/DW*

12/8/21
13/9/21
 CFO (S2)
17/9/2021
 Director
18/9/21