

c/72

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

**NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2024/SZ/ 934

Dated: 24/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Govt. Sarvodaya Co-ed Sec. Sec. School located at Possangipur, B-1, Janakpuri, New Delhi - 110058, comprised of five blocks namely Bismil, Ramanujan, and APJ Abdul Kalam having ground plus one upper floor each, Nalanda and Primary block having ground plus three upper floors & MP Hall having ground floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/708 dated 03.09.2021. The School building was re-inspected by the officer concerned of this department on dated 17.09.2024 in the presence of Sh. Ajay Kumar (HOS) and found that School building have deemed complied the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. 24/09/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 24/09/2024 at New Delhi by.

  
(Ajul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Principal, Govt. Sarvodaya Co-ed Sec. Sec. School located at Possangipur, B-1, Janakpuri, New Delhi - 110058.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, New Delhi- 110054.

**Conditions for the validity of fire safety certificate: -**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/32

School building comprises of Five blocks: Blocks namely Bismil, Ramanujan, Dr.A.P.J.Abdul Kalam having ground plus one upper floor and Nalanda & Primary block having Ground plus three upper floors and MP Hall having ground floor only (Govt. Sarvodaya Co-ed Senior Secondary School, Possangipur, B-1, Janakpuri, New Delhi - 110058)

### INSPECTION REPORT

1. Name & address of the building : Govt. Sarvodaya Co-ed Sen. Sec. School, Possangipur, B-1, Janakpuri, New Delhi - 110058
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/School/2021/SZ/708 dated 03.09.2021
5. Fire Safety directives letter No : N/A
6. Date of inspection : 17.09.2024
7. Name of Inspecting Officer : A.D.O. R.K. Yadav
8. Name and designation of officers  
From the building side : Sh. Ajay Kumar (HOS)
9. Year of Construction : Before 2011 & 2016-17
10. Applicant's letter No. : Online application Id [1618003Possangipur@gmail.com](mailto:1618003Possangipur@gmail.com) dated 19.08.2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible 4.5 m N/A	09 m provided N/A	M/R MR N/A
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	10 No's N/A	10 No's N/A	M/R N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	1.50 m N/A	1.75 m (3 No.'s in Nalanda blk), 1.75 m (1 No. in Prmy blk), 1.37 & 1.60 in Bismil blk, 1.57 x 2 in APJ blk, 1.40 & 1.64 m in Ramanujan blk N/A	M/R N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	Required	Provided	N/A
		1.5 m	1.75 m	M/R
	f. Door Size	1.0 & 2.0 in MP Hall	.97 to 1.12 m (Double Door) & 2.08 (2 No.'s) & 1.35 (4 no.'s) in MP hall	M/R
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	N/A N/A	N/A Natural Ventilation	N/A M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	30 no's ABC/CO <sub>2</sub> type  ISI marked	Provided Provided ISI marked	M/R M/R M/R

f

h

N/33

6.	<b>First-Aid Hose Reels</b> <span style="float: right;">Nalanda &amp; Primary block</span>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	2 no. in Nalanda & 1 no. of Pry. Blk. 30 m 05mm	Provided Provided Provided	M/R M/R M/R
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	<b>MOEFA</b>			
9.	<b>Public Address System</b>			
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A N/A	N/A N/A	N/A N/A
13.	<b>Pumping Arrangements</b> <span style="float: right;">Nalanda &amp; Primary block</span>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> <li>Pump House Access</li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450 lpm Nalanda & Pry blk. 40 m Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A M/R M/R M/R M/R
14.	<b>Captive Water Storage for fire-fighting</b> <span style="float: right;">Nalanda &amp; Primary block</span>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	N/A N/A N/A N/A 10,000 ltrs Nalanda & Pry blk. Required	N/A N/A N/A N/A Provided Provided	N/A N/A N/A N/A M/R M/R
15.	<b>Exit Signage.</b>			
			Provided Provided	M/R M/R

1/

W

N/34

16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	<b>Standby power supply</b>	N/A	N/A	N/A
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2021/SZ/708 dated 03.09.2021 renewal under rule, 37 of the Delhi Fire Service Rules, 2010 is recommended.

*R. K. Yadav*

Signature of Inspecting Officer  
 Name: - R.K. Yadav  
 Designation: - ADO (JKP)

DO (South West)

*18/09/24*

*19/09/2024*

*Director*

*[Handwritten signature]*

*[Handwritten signature]*