



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**



No F 6 / DFS / MS / 2024 / School / WZ / 926

Dated 24/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the MC Primary Co-ed School located at Jaunti, Delhi-110081 comprised of Ground floor only was issued FSC by this department vide letter No F6 /DFS/MS/School/2013/726 dated 19.08.2013. The premises was re-inspected by the officer concerned of this department on 12.09.2024 in the presence of Sh. Narender Singh (In-charge), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ..24.09.2024. for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on ..24.09.2024. at New Delhi by

(Atul Garg)  
Director  
Ph. 011-23414000  
du

Copy to:-

1. The Director, Education, MCD, Civic Center, Delhi.
2. The Principal, MC Primary Co-ed School located at Jaunti, Delhi-110081.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

**INSPECTION REPORT**

1. Name & address of the building : MC Primary Co-ed School located at Village Jaunti, Delhi- 110081.
2. Type of Occupancy : Educational
3. Building Comprised of : Ground floor only
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/2013/726 dated 19/08/2013
6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011
7. Date of inspection : 12/09/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Sh. Narender Singh (In-charge)
10. Year of Construction : 1973
11. Applicant's letter No. : Outdoor Diary No. 6009 dated 04/09/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	Road width	6 m	Provided	MR
	Gate width	4.5 m	Directly Accessible	MR
	Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	Number of staircases			
	Upper Floors	NA	NA	NA
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	NA	NA	NA
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	NA	NA	NA
	Width of Corridor	NA	NA	NA
	Door Size	1 m	Provided	MR
3.	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	Basements	NA	NA	NA
	Upper floors	NA	NA	NA
5.	<b>Fire Extinguishers</b>			
	Total numbers	02	03	MR
	Types	ABC Type	Provided	MR
	IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	Total numbers on each floor	NA	NA	NA
	Length of hose reel hose	NA	NA	NA
	Nozzle diameter	NA	NA	NA
7.	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA



8.	<b>MOEFA</b>	NA	NA	
9.	<b>Public Address System</b>	NA	NA	
10.	<b>Automatic Sprinkler System</b>			
	Basement	NA	NA	NA
	Ground Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	<b>Internal Hydrants</b>			
	Size of riser/down-comer	NA	NA	NA
	Number of hydrants per floor	NA	NA	NA
	Hose Box	NA	NA	NA
12.	<b>Yard Hydrants</b>			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	<b>Pumping Arrangements</b>			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	NA	NA	NA
	Head of the pump	NA	NA	NA
	Power Supply	NA	NA	NA
	Auto Starting of pump	NA	NA	NA
14.	<b>Captive Water Storage for fire fighting</b>			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	NA	NA	NA
15.	<b>Exit Signage.</b>	NA	NA	NA
16.	<b>Provision of Lifts.</b>			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	<b>Standby power supply</b>	NA	NA	NA
18.	<b>Refuge Area.</b>			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	<b>Fire Control Room</b>			
	Detector System Panel	NA	NA	NA

W Switch Panel	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans	NA	NA	NA
Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel are installed at safer location.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2013/726 dated 19/08/2013.

*[Handwritten Signature]*  
10/9/24

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

*[Handwritten Signature]*  
DO (W)

*[Handwritten Signature]*  
17/09/2024

*[Handwritten Signature]*  
DY CFO (W)

*[Handwritten Signature]*  
12/8

06-N/A  
09-24

*[Handwritten Signature]*  
CFO  
18/9/2024

*[Handwritten Signature]*  
Director  
10/9/24

*[Handwritten Note]*  
Adm/BW Sm. FT letter in reference to  
MMS

*[Handwritten Signature]*  
10/9/24

*[Handwritten Signature]*  
Director  
*[Handwritten Signature]*