

cl/15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2024/ 308

Dated: 24/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Adyar Ananda Bhavan Sweets India Pvt. Ltd., 54, Janpath Street, Connaught Place, Delhi -110001 in a building comprises of basement , ground + 03 upper floor and restaurant is running at ground floor only. The restaurant premises was inspected by the officers concerned of this department on 12/09/24 in the presence of Mr. Bala ji, Manager and found that the said restaurant premises has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant premises is fit for occupancy class **Assembly - Group D** – Restaurant at ground floor only and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ...24/09/2024..... at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect NDMC Palika Kendra, New Delhi: to kindly ensure the occupancy as above and deviation in construction if any.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi. Id No. 2024082313052 dated 23.08.2024.
3. The Manager, Adyar Ananda Bhavan Sweets India Pvt. Ltd., 54, Janpath Street, Connaught Place, Delhi -110001.

Conditions for the validity of fire safety certificate

1. This FSC is valid for restaurant at ground floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape such as exits, corridor, etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Basement shall be used for storage only as per BBL concerned

N/2
INSPECTION REPORT

1. Name & address of the building Adyar Ananda Bhavan Sweets India Pvt. Ltd., 54, Janpath Street, Connaught Place, Delhi -110001.
2. Type of occupancy:- Assembly Building Group-D
 Restaurant at Ground floor only.
3. Type of case:- New Case
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 12/09/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
 Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer
 from the building side:- Mr. Bala Ji
9. Year of construction:- 2024
10. Applicant's letter No:- online id no.2024082313052 dated 23.08.2024.

The building is comprised of basement, ground and three upper and said restaurant is running at ground floor and the building has already issued the FSC vide letter no. F6/DFS/MS/GH/2022/84 dated 24.02.2022 under mercantile /office occupancy.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements.	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr	09 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.5 x2mtr.	Provided . /	MR
3.	Compartmentation			
	1) Fire check door (kitchen)	Required	Provided	MR
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			

N/B

	1) Total numbers	04 Nos.	4 Nos.	MR
	2) Type	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number at floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Provided	MR
	2) Location of main panel	ground	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	ground	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided	MR
	2) Upper floors (Gr. Floor)	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement	(combined fire & pump arrangements)		
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450x2 LPM	MR
	b) Head of pump	35 mtr.	35 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting (combined fire fighting arrangements)			
	1) Under ground tank capacity	N/A	N/A	N/A

2

2/4


	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	20,000 ltr.	30,000 ltr. ✓	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & Co2			MR


The fire protection systems provided in the restaurant were randomly tested, checked and found functional at the time of inspection.




In view of the substantial compliance minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may issue FSC to said restaurant at ground floor only. Accordingly, DFA is prepared and put up for kind perusal and sig. please.

Signature of the Inspecting Officer

Signature of the Inspecting Officer


 Name :- Sh. Rajinder Atwal
 Designation :- DO (CD)


 Name :- Sh. Ravinder Singh
 Designation : ADO (CC)


 Dy. CG (N2)
 C.F.O.

 Director
 20/9/2011

 Director
 18/09/2011
