

No. F6/DFS/MS/WZ/School/2024/WZ/ 943

Dated:- 26/09/2024

FIRE SAFETY CERTIFICATE

Certified that the B.S. International School Located at Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041, comprised of Ground + 02 Upper Floors only owned/occupied by Shri Dalip Singh Educational & Welfare Society, was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2021/WZ/778 dated 27/09/2021. The said premise was re-inspected by the officer concerned of this department on 13/09/2024 in the presence of Sh. Anoop Shokeen (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 262-362 dated 17/01/2005 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 26/09/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 26/09/2024 at New Delhi by

(Anul Garg)
Director

Tel No. 011-23414000

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, B.S. International School, Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi- 110041.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **B.S. International School** located at **Plot No. 26, Dalip Vihar, Nilothi Extn., New Delhi-110041**
2. Type of Occupancy : Educational (G + 02 Upper Floor only)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2021/WZ/778 Dated 27/09/2021
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 262-362 dated 17/01/2005
6. Date of inspection : 13/09/2024
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer
from the building side : Sh. Anoop Shokeen (Manager)
9. Year of Construction : 2009
10. Applicant's letter No. : Email dated 06/09/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 262-362 dated 17/01/2005/as per FSC dated 27/09/2021		Provided at site	Remarks MR/NMR
1.	Access of building				
	• Road width	06 m	Provided		MR
	• Gate width	4.5 m	Provided		MR
	• Width of internal road	NA	NA		NA
2.	Number, width, Type & Arrangements of exits				
	a. Number of staircases				
	• Upper floors	02	02		MR
	• Basements	NA	NA		NA
	b. Width of staircases				
	• Upper floors	1.5 m	1.5 m x 2		MR
	• Basements	NA	NA		NA
	c. Protection of exits				
	• Fire check door	NA	NA		NA
	• Pressurization	NA	NA		NA
	d. No of continuous staircase to terrace	NA	NA		NA
	e. Width Of Corridor	1.5 m	2.70 m		MR
	f. Door Size	1 m	1.10 m		MR
3.	Compartmentation			NA	
	• Fire check door	NA	NA		NA
	• Sealing of electrical shafts	NA	NA		NA
	• Fire Rating of shaft door	NA	NA		NA
	• Water Curtain	NA	NA		NA
	• Fire Dampers	NA	NA		NA
4.	Smoke managements System				
	• Basements	NA	NA		NA
	• Upper floors	NA	NA		NA
5.	Fire Extinguishers				
	• Total numbers	06 nos.	Provided		MR
	• Types	ABC & CO ₂	Provided		MR
	• ISI marking	ISI Marked	Provided		MR
6.	First - Aid Hose Reel				

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 05 mm	Provided Provided Provided	M M MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	Provided NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 450 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA 450 lpm x 2 40 m Provided Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 2,500 ltrs.	NA NA NA NA 4,000 ltrs.	NA NA NA NA MR MR
15	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA NA	NA NA	NA NA
19.	Fire control room			
	<ul style="list-style-type: none"> Detector system panel 	NA NA	NA NA	NA NA

	<ul style="list-style-type: none"> ➤ Flow Switch Panel ➤ PA System Panel ➤ Battery backup ➤ Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 262-362 dated 17/01/2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2021/WZ/778 Dated 27/09/2021 is recommended.

Accordingly DFA is prepared for approval & signature please.

~~DCFO (JWP)~~

Quitta #
19/09/24
Aman Kumar Lathar
ADO (JWP)

[Signature]
19/9/2024

CFO
[Signature]
20/9/2024
Director
[Signature]
29/9/24
ADO (JWP)

Sir,
F.I. letter is put-up for your signature pl.

[Signature]
[Signature]
MKR

Quitta #
24/09/24
ADO (JWP)