



FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sr. Sec. School No.1 located at Ghonda Delhi - 110053, building comprised of Old Building (Ground + 01 Upper floor) & New Building (Ground + 03 Upper floors), owned /occupied by Govt. Girls Senior Secondary School No. 1, was issued FSC vide letter No. F6/DFS/MS/School/2022/NDZ/301 dated 21/03/2022 (Old Building) & F6/DFS/MS/School/2021/NDZ/726 dated 09/09/2021 (New Building). The School building was re-inspected by the officer concerned of this department on 18/09/2024 in presence of Mrs. Anju Pathak (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class (Group-B) "Educational Building" with effect from 26/09/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 26/09/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Principal, Govt. Girls Sr. Sec. School No.1 located at Ghonda Delhi - 110053.
2. The Joint Director of Education, B- Block, Yamuna Vihar, Delhi - 110053.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/26
INSPECTION REPORT

01.	Name & address of the building	Govt. Girls Sr. Sec. School No.1 located at Ghonda Delhi-110053.		
02.	Building is comprised of	Old Building (Ground + 01 floor) & New Building (Ground + 03 floors)		
03.	Type of occupancy	Educational Building		
04.	Type of case	Renewal		
05.	Details of previous FSC	F6/DFS/MS/School/2022/NDZ/301 dated 21/03/2022 (Old Building) F6/DFS/MS/School/2021/NDZ/726 dated 09/09/2021 (New Building)		
06.	Fire safety directives letter no.	NBC Part - IV		
07.	Date of inspection	18/09/2024		
08.	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
09.	Name of the designation of officer from the building side	Mrs. Anju Pathak (Principal)		
10.	Year of construction	1949 & 2018		
11.	Applicant's letter no.	Email dated 10/09/2024		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
01.	Access to Building:			
A	Road width	6.0 mtrs.	07 mtrs.	MR
B	Gate width	4.50 mtrs	5.20 mtrs	MR
C	Width of internal road	N/A	N/A	N/A
02.	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
A	Upper floor New Building (G+3)	02 nos.	02 nos.	MR
B	Upper floor Old Building (G+1)	04 nos.	04 nos.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor Old Building (G+1)	1.5 mtrs. ✓	1.5 mtrs each ✓	MR
	Upper floor New Building (G+3)	1.5 mtrs. ✓	1.70 mtrs. each ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace Old Building (G+1)		N/A	N/A
	No. of continuous staircases to terrace New Building (G+3)	01 no	01 no	MR
E	Width of corridor Old Building (G+1)	1.5 mtrs.	1.60 mtrs	MR
	Width of corridor New Building (G+3)	1.5 mtrs	1.73 mtrs. ✓	MR
F	Door size Old Building (G+1)	01 mtrs.	01 mtr ✓	MR
	Door size New Building (G+3)	1.20 mtrs.	1.20 mtrs. ✓	MR
03.	Compartmentation:			
A	Fire check door	N/A	N/A	N/A
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
04.	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

05. Fire Extinguisher:				
A	Total numbers Old Building (G+1)	22 nos.	22 nos.	MR
	Total numbers New Building (G+3)	17 nos.	18 nos.	MR
B	Types	ABC/CO ₂	ABC/CO ₂	MR
C	ISI marking	ISI Marked	ISI Marked	MR
06. First-Aid-Hose Reels				
A	Total numbers of each floor (G+3) New building	01 no.	02 nos.	MR
	Total numbers of floor (G+1) Old building	N/A	N/A	N/A
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
07. Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
08.	MOEFA:	N/A	N/A	N/A
09	Public Address System Old Building (G+1)	N/A	Provided	MR
	Public Address System New Building (G+3)	N/A	N/A	N/A
10. Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11. Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12. Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13. Pumping Arrangements:				
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump Old Building (G+1)	N/A	N/A	N/A
	Discharge of pump New Building (G+3)	450 LPM	450 LPM X 2	MR
B	Head of the pump	40M	40M	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14. Captive Water Storage for Fire Fighting:				
A	Underground tank capacity old building (G+1)	N/A	N/A	N/A
B	Underground tank capacity New Building (G+3)	N/A	N/A	N/A
C	Draw-off connection	N/A	N/A	N/A
D	Fire service inlet	N/A	N/A	N/A
E	Access to tank	N/A	N/A	N/A
F	Overhead tank capacity Old Building (G+1)	N/A	N/A	N/A
G	Overhead tank capacity New Building (G+3)	10,000 liters. ✓	10,000 liters. ✓	MR
15. Exit Signage: Old Building (G+1)		N/A	N/A	N/A
Exit Signage: New Building (G+3)		Required	Provided	MR
16. Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17. Standby Power Supply:		NA	N/A	N/A
18. Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19. Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20. Special Fire Protection systems for protection of special Risks, if any:		NA	N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2022/NDZ/301 dated 21/03/2022 (Old Building) & F6/DFS/MS/School/2021/NDZ/726 dated 09/09/2021 (New Building), renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.



19/9/2024

Signature of the Inspecting Officer

Name: - Yashwant Singh Meena

Designation: - ADO (L.N)

DY. CFO/NDZ

C.F.O.

Director

19/09/24
20/9/2024
20/9/24

ADO/LN

P.T.O