



No. F6/DFS/MS/Petrol/NDZ/2024/ 575

Dated: 23/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Storage of Petroleum Class A & B** located at **Kargil heights Filling Station, Vasundhara, Kondli Road, Chilla Sports Complex (DDA), Delhi - 110096**, comprised of **ground floor only** owned/occupied by **M/s Kargil heights Filling Station** was issued FSC vide letter No. F6/DFS/MS/NDZ/2021/Petrol/438 dated 08.09.2021. The premises was re-inspected by the officer concerned of this department on 13/09/2024 in presence of Mrs. Meena Nayyar (Proprietor) & Mr. Ajay Kumar (Manager) and found that the said filling Station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Storage of Petroleum Class A & B (A - 20 KL & B - 40 KL)**" with effect from 23/09/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 23/09/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

OK W
DELHI FIRE SERVICE

Copy to: -

1. The Manager, Kargil heights Filling Station, Vasundhara, Kondli Road, Chilla Sports Complex (DDA), Delhi - 110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
8. No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.

INSPECTION REPORT

1	Name & address of the building	Storage of petroleum Class A & B located at Kargil heights Filling Station, Vasundhara, Kondli Road, Chilla Sports Complex (DDA), Delhi.			
2	Building is comprised of	Ground floor only.			
3	Type of occupancy	Storage of Petroleum Class A & B (A - 20 KL & B - 40 KL)			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/NDZ/2021/Petrol/438 dated 08.09.2021			
6	Fire safety directives letter no.	NA			
7	Date of inspection	13/09/2024			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side	Mrs. Meena Nayyar (Proprietor) & Mr. Ajay Kumar (Manager)			
10	Year of construction	2021			
11	Applicant's letter no.	Outdoor Diary No. 6127 dated 06/09/2024			
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	12 meters.	20 meters	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
		a	Upper floor	N/A	N/A
		b	Basement	N/A	N/A
	B	Width of staircases			
		a	Upper floor	N/A	N/A
		b	Basement	N/A	N/A
	C	Protection of exits			
		a	Fire check door	N/A	N/A
		b	Pressurization	N/A	N/A
	D	No. of continuous staircases to terrace			
	E	Width of corridor			
	F	Door size & No. of Doors			
3	Compartmentation:	Required	Provided	MR	
4	Smoke Management System:	Required	Provided	MR	
	A	Basement	N/A	N/A	
	B	Upper floor	Required	Provided	

3

5.	Fire Extinguisher:			
A	ABC type 50 Kg	01 no.	01 no.	MR
B	ABC type 05 Kg	06 nos.	06 nos.	MR
C	DCP type 4.5 Kg	19 nos.	19 nos.	MR
D	Co 2 type 4.5 Kg	04 nos.	04 nos.	MR
E	ISI Marking	Required	Provided	MR
6	First-Aid-Hose Reel:			
A	Total numbers of each floor	N/A	N/A	N/A
B	Length of hose reel hose	N/A	N/A	N/A
C	Nozzle diameter	N/A	N/A	N/A
7	Automatic Fire Detection and Alarming System:			
A	Type of detectors	Heat	Provided	MR
B	Location of main panel	Required	Provided	MR
C	Location of repeater panel	Required	Provided	MR
D	Alternate source of power	Required	Provided	MR
E	Hooters	Required	Provided	MR
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10	Automatic Sprinkler System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:			
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	N/A	N/A	N/A
B	Head of the pump	N/A	N/A	N/A
C	Power supply	N/A	N/A	N/A
D	Auto starting of pump	N/A	N/A	N/A

(3)

2


19/10

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	N/A	N/A
15	Exit Signage / No Smoking Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The Fire Safety Certificate was issued vide letter no. F6/DFS/MS/NDZ/2021/Petrol/438 dated 08.09.2021 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

No file is pending with me before disposal of this case.


 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (L.N)

~~DY. CEO/NDZ~~

~~King
17/09/24~~

~~C.F.O.~~

~~19/09/2024~~

~~Director/NDZ
20/9/24~~

P.T.O