



No. F6/DFS/MS/School/NDZ/2024/ 941

**FIRE SAFETY CERTIFICATE**

Certified that the **Lovely Public Senior Secondary School** located at Block A - Plot no. 251, Block B - Plot no. 225 & Block C - Plot no. 201, New Loyalpur, Delhi - 110051, comprised of three blocks (A, B & C) each block having ground plus three upper floors owned/occupied by **Lovely Public Senior Secondary School** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/NDZ/728 dated 09/09/2021. The School building was re-inspected by the officer concerned of this department on 03/09/2024 in presence of Dr. Inder Malik (Principal) and found that school have deemed complied with the fire prevention and fire safety requirements in accordance with Circular letter No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class **Group B "Educational Building"** with effect from 26 /09/2024 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 26/09/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

**Copy to: -**

1. The Joint Director of Education (Land & Estate), Directorate of Education, Lucknow Road, Delhi - 110054.
2. The Principal, Lovely Public Senior Secondary School located at Block A - Plot no. 251, Block B - Plot no. 225 & Block C - Plot no. 201, New Loyalpur, Delhi - 110051.

**Conditions for the validity of Fire Safety Certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



**INSPECTION REPORT**

1	Name & address of the building	Lovely Public Senior Secondary School located at Block A - Plot no. 251, Block B - Plot no. 225 & Block C - Plot no. 201, New Layalpur, Delhi - 110051.		
2	Building is comprised of	Ground plus three upper floors. (A, B & C Blocks)		
3	Type of occupancy	Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2021/NDZ/728 dated 09/09/2021		
6	Fire safety directives letter no.	Old Requirement Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	03/09/2024		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Sunita Dhingra (Manager)		
10	Year of construction	1988		
11	Applicant's letter no.	Outdoor dairy no. 5324 dated 16/08/2024		
S.No	<b>Minimum standard of fire prevention and fire safety U/R 33</b>	<b>Old Circular Requirement</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1	<b>Access to Building:</b>			
A	Road width	6.0 mtrs.	7.0 mtrs. ✓	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	Number of staircases ✓			
a	Upper floor	02 nos. each block	02 nos. each block	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.5 mtrs. each block	Block A- 1.50 mtrs, 1.0 mtr & 1.0 mtr. Block B- 1.14 mtr, 1.15 mtr, & 1.10 mtr. Block C- 1.35 mtr & 1.40 mtr.	MR (Accepted earlier)
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no.	01 no.	MR
E	Width of corridor	1.50 mtrs. each block	1.50 mtrs. each block ✓	MR
F	Door size	1.0 mtr.	1.0 mtr.	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A

<b>5. Fire Extinguisher:</b>				
A	Total numbers	15 nos.	24 nos.	MR
B	Types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
C	ISI marking	ISI Marked	Provided	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers of each floor	01 no. each block	01 no. each block	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	50 mm	05 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	Provided	MR
<b>8 MOEFA:</b>		N/A	N/A	N/A
<b>9 Public Address System:</b>		N/A	Provided	MR
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box	01 no.	01 no.	MR
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>				
A	Discharge of pump	450 LPM each block	450 LPM each block	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Required	MR
D	Auto starting of pump	Required	Required	MR



<b>14</b>	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5,000 litres each block	5,000 litres each block	MR
		Required	provided	MR
<b>15</b>	<b>Exit Signage:</b>			
<b>16</b>	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
<b>17</b>	<b>Standby Power Supply:</b>			
<b>18</b>	<b>Refuge Area:</b>			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
<b>19</b>	<b>Fire Control Room:</b>			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.


Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of Directorate of Education the FSC issued vide letter no. F6/DFS/MS/School/2021/NDZ/728 dated 09/09/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended to be renewed.  
No file is pending with me before disposal of this case.

  
4/9/2024

Signature of the Inspecting Officer  
Name: Yashwant Singh Meena  
Designation: ADO (Laxmi Nagar)

~~Y.CFO/NDZ~~

  
05/09/28

C.F.O.   
7/9/2024

  
Director



P.F.O