

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/Hospital/NDZ/2024/ 573

Dated: 23/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Tirath Ram Shah Charitable Hospital** located at **2A, Isher Das Sawhney Marg, Rajpur Road, Delhi - 110054**, comprised of Basement + Ground + 03 upper floors was granted FSC by this department vide letter no. F6/DFS/MS/Hospital/NDZ/2021/384 dated 11.08.2021. The premises was re-inspected by the team of officers concerned of this department on 04.09.2024 in presence of Mr. Hira Adhikaris (Admin.) and found that the said hospital building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy of class **"Institutional Building (Hospital)"** with effect from 23/09/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 23/09/2024 at New Delhi by

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel.-011-23414000  
d/c  
02/11/24

**Copy to:-**

1. The Commissioner,  
Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 02.
2. Dr. J. P. Singh (Medical Director),  
Tirath Ram Shah Charitable Hospital, 2A, Isher Das Sawhney Marg, Rajpur Road, Delhi-54.

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

## INSPECTION REPORT

1.	Name and address of the building:	Tirath Ram Shah Charitable Hospital, 2A, Isher Das Sawhney Marg, Rajpur Road, Delhi - 54.
2.	Type of occupancy with details of floors:	Institutional Building (Basement + Ground + 03 upper floors)
3.	Type of case:	Renewal
4.	Details of previous FSC:	F6/DFS/MS/Hospital/NDZ/2021/384 dated 11.08.2021
5.	Fire safety directives no.:	Nil
6.	Date of inspection:	04.09.2024
7.	Name of the inspecting officer:	Rajinder Atwal, DO (CD) & Sumit Kumar, ADO (SPM)
8.	Name and designation of the officer from the building side:	Mr. Hira Adhikari (Admin.)
9.	Year of construction:	1954
10.	Reference letter no.:	Letter no. TRSH/Admn./2024-25/34 dated 26.07.2024

S, No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements Existing fire safety arrangements	Provide at site	Remarks MR/NM/R	
1	Access to Building				
	A	Road width	Approachable	30 feet	MR
	B	Gate width	4.75 m	4.75 m	MR
	C	Width of internal roads	NA	Approachable on two side	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. Of Staircase:			
		a) Upper Floor	03 Nos.	03 Nos.	MR
		b) Basements	02 nos.	02 nos.	MR
	B	Width of the Staircase:			
		a) Upper floors	1.45 m, 1.45 m & 1.5 m	1.45 m, 1.45 m & 1.5 m	MR
		b) Basements	2.0 m & 1.0 m	2.0 m & 1.0 m	MR
	C	Protection of Exits			
		a) Fire Check Door in basement	Required	Provided in one staircase at basement	MR
		b) Pressurization	NA	NA	NA
	D	No. Of continuous staircase to terrace:	NA	NA	NA
	E	Width of the corridor	NA	NA	NA
	F	Door size	1.10 m	1.10 m	MR (old case)
3	Compartmentation:				
	A	Fire Check doors	Required	Provided	MR
	B	Sealing of Electrical Shafts	NA	NA	NA
	C	Fire rating of shaft Doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
		Fire dampers	NA	NA	NA
4	Smoke management System:				
	A	Basements	30 ACPH	Exhaust fan	MR
	B	Upper floors	12 ACPH	Natural	MR
5	Fire extinguishers				
	A	Total numbers	42 nos.	42 nos.	MR
	B	Types	CO2, ABC	CO2, ABC	MR
	C	ISI marking	Required	Provided	MR

6/24


6	First Aid Hose reel				
	A	Total no. at each floor	03 Nos.	03 Nos.	MR
	B	Length of Hose Reel	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS)				
	A	Type of Detectors (smoke/heat)	Required	Provided	MR
	B	Location of main Panel	Required	Provided at ground floor	MR
	C	Location of Repeater Panel	NA	NA	NA
	D	Alternate power Source	Required	Provided	MR
	E	Hooter's location	Staircase	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	Required	Provided	MR
	B	Upper Floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	100 mm	100 mm	MR
	B	No. Of hydrants per floor	03 nos.	03 nos.	MR
	C	Hose box	03 nos.	03 nos.	MR
12	Yard Hydrants				
	A	Total no. of hydrants	05 nos.	05 nos.	MR
	B	Hose box	05 nos.	05 nos.	MR
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	1620 LPM	1620 LPM	MR
		b) Head of main pump	45 m	45 m	MR
		c) Number of main pump	01 no.	01 no.	MR
		d) Discharge of jockey pump	180 LPM	180 LPM	MR
		e) Head of jockey pump	45 m	45 m	MR
		f) Discharge of Standby pump	1620 LPM	1620 LPM	MR
		g) Head of Standby pump	45 m	45 m	MR
		h) Auto starting/ manual stopping	Required	Provided	MR
	B	Terrace Level			
		a) Discharge of terrace pump	NA	NA	NA
		b) Head of terrace pump	NA	NA	NA
		c) Alternate power supply	NA	NA	NA
		d) Auto starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	1,00,000 Ltrs	1,00,000 Ltrs	MR
	B	Draw off connection	Required	Provided	MR
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	10,000 ltrs.	10,000 Ltrs	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	Required	Provided	MR
	D	Fireman's switch	Required	Provided	MR
	E	Lift signage	Required	Provided	MR
17	Standby Power Supply		Required	2 nos. DG set 125 KVA & 625 KVA	MR


✓ 6 ④


18	Refuge Area				
	A	location	NA	NA	NA
	B	Total area	NA	NA	NA
19	Fire Control Room				
	A	Fire Detection System panel	Required	Provided	MR
	B	Flow switch panel	NA	NA	NA
	C	P A system panel	Required	Provided	MR
	D	Battery backup	Required	Provided	MR
	E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any: HT/LT panel Co2 type fire extinguisher				MR


The fire protection system provided in the building was randomly checked and tested and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter No. F6/DFS/MS/Hospital/NDZ/2021/384 dated 11.08.2021 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

  
 12/9/24  
 Signature of the Inspecting Officer  
 Name Rajinder Atwal  
 Designation DO (CD)


  
 12/09/2024  
 Signature of the Inspecting Officer  
 Name Sumit Kumar  
 Designation ADO (SPM)

~~Dy. CFO (NDZ)~~   
 13/09/24

~~C.F.O.~~   
 17/9/2024



~~Director~~   
 18/9/24



  
 18/9/24  
 ADO (SPM)

f.T. letter is put up for signature, please.

  
 19/09/2024

~~D.O. (CD)~~  
  
 19.9.24  
 Director   
 19/9/24

