

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/2024/SZ/ 589

Dated: 26/09/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Hahnemann Pharmaceuticals Pvt. Ltd. Located at A-7, Naraina Industrial Area, Phase-1, New Delhi – 110028 running in 07 rooms and one hall at Mezzanine, first & second floor in a building comprised of Basement, Ground, Mezzanine & 02 Upper Floors was issued Fire Safety Certificate issued by this department vide letter No. F6/DFS/MS/SZ/2021/67, dated 27/01/21. The premises was inspected by the officer concerned of this department on 18/09/2024 in the presence of Ms. Neeru Narula (Managing Director) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rules as per previous FSC No F6/DFS/MS/SZ/2021/67, dated 27/01/21 and that the building is fit for occupancy class "Industrial" with effect from 26/09/2024 for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/09/2024 at New Delhi by.


(Anil Garg)
Director,
Delhi Fire Service

Copy to:

1. The Manager, Hahnemann Pharmaceuticals Pvt. Ltd. Located at A-7, Naraina Industrial Area, Phase-1, New Delhi - 110028.
2. The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi.

Conditions for validation of Fire Safety Certificate:-

1. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
8. Basement shall be used strictly as per building bye laws.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Hahnemann Pharmaceuticals Pvt. Ltd.
Located at A-7, Naraina Industrial Area, Phase-1, New Delhi - 110028.
2. Type of Occupancy : Business
3. Type of Case : Renewal (Running in 07 rooms & 01 hall at Mezzanine, first & second floor in a building comprised of Basement, Ground, Mezzanine & 02 Upper Floors)
4. Details of previous NOC : F6/DFS/MS/SZ/2021/67, dated 27/01/21
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 18/09/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Ms. Neeru Narula (Managing Director)
9. Year of Construction : Before 1993
10. Applicant's letter No. : nil, dated 19/07/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/4, N/5 & N/6 | Provided at site | Remarks MR/NMR |
|------|---|-----------------------|-----------------------------|---------------------|
| 1. | Access of building | | | |
| | • Road width | 6 mtr | Provided | MR |
| | • Gate width | NA | Direct accessible from road | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 01 | 01 | MR (Being old case) |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | Old case | 0.88 to 1.18m | MR (Being old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | NA | NA | NA |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size | Old case | 0.85 m | MR (Being old case) |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |




| | | | | |
|-----|--|-----------------------|-----------------------|----|
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | NA | NA | NA |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 08 Nos. | Provided | MR |
| | • Types | ABC & CO ₂ | CO ₂ & ABC | MR |
| | • IS marking | Required | Provided | MR |
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down- comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | MR |
| | ➤ Head of the pump | NA | NA | MR |
| | ➤ Power supply | NA | NA | MR |
| | ➤ Auto starting of pump | NA | NA | MR |


[Handwritten signature]




| | | | | |
|-----|--|----------|----------|----|
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/SZ/2021/594 dated 30-11-2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


Signature of the Inspecting Officer
Name: Sh. Udaivir Singh
Designation : ADO (DWK)




CFO(S2) 
21/9/2021
Director 
23/9/2021

