

9/142

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No. F6/DFS/MS/WZ/EH/2024/ 310

Dated: 25/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s. Bikanervala Pvt. Ltd. Located at Plot No. 07, Ground Floor and First Floor, Block 02, WHS, Industrial Area, Kirti Nagar, New Delhi - 110015, in a building comprised of Basement + Ground + 3 Upper Floors, owned/occupied by M/s. Bikanervala Pvt. Ltd, Fire Safety Certificate was already issued by this department vide letter no. F6/DFS/MS/EH/WZ/2021/242 dated 22/09/2021. The premises was re-inspected by the officer of this department on 18/09/2024 in the presence of Sh. Jaspal Singh (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises/ building found in good working condition. The said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire service Rules, 2010 and that the building / premises is fit for occupancy class "Assembly" (Group-D) and valid upto 31/03/2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 conditions printed overleaf.

Issued on 25/09/2024 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service\*

25/9/2024

Copy to:

1. The owner/occupier, M/s. Bikanervala Pvt. Ltd, Located at Plot No. 07 Ground Floor and First Floor Block 02 WHS Kirti Nagar, New Delhi - 110015.
2. The Deputy Health Officer, Karol Bagh, MCD, Anand Parbat, New Delhi - 110005.

M19

## INSPECTION REPORT

1. Name & address of the building	M/s Bikanervala Pvt. Ltd, Located at shop/property no. Plot No. 07, Ground Floor and First Floor, Block 02, WHS, Industrial Area, Kirti Nagar, New Delhi – 110015.
2. Type of Occupancy	Eating House /Assembly Occupancy
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/WZ/2021/242 dated 22/09/2021
5. Fire Safety directives letter No	Nil
6. Date of inspection	18/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Jaspal Singh (Manager)
9. Year of Construction	1994 (As per MHA Portal)
10. Applicant's letter No.	Online Application ID No. 2024082813210 dated 03/09/2024

The Said Restaurant is running at ground & first floor, in a building comprised of basement, ground & 03 upper floors, was issued FSC by this department vide letter No. F6/DFS/MS/EH/WZ/2021/242 dated 22/09/2021.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 m	Provided	MR
	• Gate width	4.5m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	2 X 1.5m	2 X 1.5m Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	2m & 1m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	12	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

87

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
		NR	NR	NR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>			
		Required	Provided	MR

214

Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The Fire Protection system provided in the building were tested/ checked and found functional at the time of inspection.

1/ASD/MN

19/09/2024

In view of the deemed compliance of minimum standards of fire prevention and fire safety as required under rules the NOC issued vide letter no. F6/DFS/MS/EH/WZ/2021/242 dated 22/09/2021 renewal under rule 35 of the Delhi fire service Rules 2010 is recommended.

*Qy CFO (12)*

*ASD*  
19/9/2024

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

*ASD*  
19/9/2024

*CFO*  
Dated... 10/09/2024

*CFO*  
*ASD*  
20/9/2024  
*Director*  
24/9/24

*Sir, F.T is put up*

*for your kind personal & signature pls.*

*Director*  
24/9/24

*ASD*  
23/9/24

*Uploaded*