

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/EH/2024/SZ/ 313

Dated 25/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the name & Style of **M/s CHIC - Fish** located at 32 Corner Market, Maharishi Dayanand Marg, Malviya Nagar, New Delhi 110017 Comprised of Ground Plus One Upper Floors, but **restaurant running at Ground floor only** owner/occupied by M/s CHIC - Fish was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2021/SZ/273 Dated 05/10/2021. The restaurant premise was re-inspected by the officer concerned of this department on 19/09/2024 in the presence of Mr. Jagdish Raj found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class D "Assembly Building"** Restaurant at Ground Floor only and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/09/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint C.P (Lic) 1st Floor, PS Defence Colony, New Delhi 110049. Ref. MHA Portal ID 2024082813222 dated 28/08/2024)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	Road width	Required	10 mtr	MR
	Gate width	N/A	N/A	N/A
	Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	Upper floors.	N/A	N/A	N/A
	Basement floor.	N/A	N/A	N/A
	b. Width of Staircase			
	Upper floors	N/A	N/A	N/A
	c. Basement floor	N/A	N/A	N/A
	d. Protection of exits			
	Fire check door	N/A	N/A	N/A
	e. Pressurization	N/A	N/A	N/A
	f. No. of continuous staircase to terrace	N/A	N/A	N/A
	g. Width of corridor	N/A	N/A	N/A
	h. Door size	2 exits	2mtr & 1 mtr	MR
3	Compartmentation.			
	Fire check door.	N/A	N/A	N/A
	Sealing of electrical shafts.	N/A	N/A	N/A
	Fire rating of shaft door.	N/A	N/A	N/A
	Water curtain	N/A	N/A	N/A
	Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	Basement	12 ACPH	N/A	N/A
	Upper floors	12 ACPH	Provided in kitchen	MR
5	Fire Extinguishers.			
	Total numbers	06 Nos	10 Nos	MR
	Types	ABC/CO ₂	ABC & CO ₂	MR
	ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	Total numbers on each floor.	One	Provided	MR
	Length of hose-reel hose.	30m	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection & alarming system.			
	Type of detectors	N/A	N/A	N/A
	Location of Main Panel	N/A	N/A	N/A

	Location of Repeater Panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System	N/A	N/A	N/A
10	Automatic Sprinkler System			
	Basement	N/A	N/A	N/A
	Restaurant area	Required	Provided	MR
	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants.			
	Size of Riser/Down-comer	N/A	100 mm	N/A
	Number of Hydrant per floor	N/A	One	N/A
	Hose box.	N/A	One	N/A
12	Yard Hydrants.			
	Total number of hydrants.	N/A	N/A	N/A
	Hose box.	N/A	N/A	N/A
13	Pumping arrangements.			
	Ground Level			
	Discharge of main pump.	N/A	N/A	N/A
	Head of main pump.	N/A	N/A	N/A
	Number of main pumps.	N/A	N/A	N/A
	Jockey Pump output.	N/A	N/A	N/A
	Jockey Pump head.	N/A	N/A	N/A
	Standby Pump output.	N/A	N/A	N/A
	Standby Pump head.	N/A	N/A	N/A
	Auto Starting/Manual Stopping.	N/A	N/A	N/A
	Pump house access.	N/A	N/A	N/A
	Terrace Level			
	Discharge of pump.	450 LPM	Provided	MR
	Head of pump.	40m	Provided	MR
	Power supply.	Required	Provided	MR
	Auto starting of pump.	Required	Provided	MR
14	Captive water storage for fire fighting.			
	Underground tank capacity.	N/A	N/A	N/A
	Draw-off connection.	N/A	N/A	N/A
	Fire Service Inlet.	N/A	N/A	N/A
	Access to tank.	N/A	N/A	N/A
	Overhead tank capacity.	5,000 Ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of lift shaft.	N/A	N/A	N/A
	Pressurization of lift lobby.	N/A	N/A	N/A
	Communication in lift car.	N/A	N/A	N/A
	Fireman's switch.	N/A	N/A	N/A
	Lift signage.	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room.			
	Detector system panel.	N/A	N/A	N/A
	Flow switch panel.	N/A	N/A	N/A
	PA system panel.	N/A	N/A	N/A
	Battery backup.	N/A	N/A	N/A

	Building floor plan.	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/EH/2021/SZ/273 Dt. 05/10/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Handwritten signature]

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

[Handwritten signature]
20/9/24

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

[Handwritten signature]
20/9/24
Director

[Handwritten signature]
ADP/B/P

As approved, f.p. letter is put up for your signature pl

[Handwritten signature]
25/9/24
Director

[Handwritten signature]
24/9

[Handwritten signature]
mul

Uploaded
20/9/24
[Handwritten signature]