



**FIRE SAFETY CERTIFICATE**

Certified that the M/s Mother Dairy Fruit & Vegetable Private Limited located at Mother Dairy Patparganj, Delhi - 110092, comprised of ground plus two upper floors owned/occupied by M/s Mother Dairy Fruit & Vegetable Private Limited was granted FSC vide letter no. F6/DFS/MS/IndI/NDZ/2021/537 dated 29/10/2021. The Premises was inspected by the officer concerned of this department of 13/09/2024 in the presence of Mr. Rahul Jain & Mr. Vishwash Bhardwaj and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group - G "Industrial building" ground plus two upper floors only valid up to 25/09/2024 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010, printed bellow.

Issued 25/09/2024 at New Delhi by.

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

**Copy to:-**

1. The Plant Incharge, M/s Mother Dairy Fruits & Vegetable Private Limited located at Mother Dairy Patparganj, Delhi - 110092.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting stall should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of any emergency.
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J'[Sub rule (1) of rule 37] along with a copy of this Certificate, Six month prior to its expiry.

N/23

**INSPECTION REPORT**

1	Name & address of the building	M/s Mother Dairy Fruits & Vegetable Private Limited located at Mother Dairy Patparganj, Delhi - 110092.		
2	Building is comprised of	Gr. + 02 upper floors		
3	Type of occupancy	Industrial Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/IndI/NDZ/2021/537 dated 29/10/2021		
6	Fire safety direction letter no.	N/A		
7	Date of inspection	13/09/2024		
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)		
9	Name of the designation of officer From the building side	Mr. Rahul Jain(Safety Officer) & Mr. Deepak Mittal (Plant In charge)		
10	Year of construction	1991		
11	Applicant's letter no	Outdoor Dairy No. 4987 dated 06/08/2024		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement Existing dt. 1.515	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
a	Road width	06 mtrs.	12 mtrs. ✓	MR
b	Gate width	4.5 mtrs	06 mtrs ✓	MR
c	Width of internal road	06 mtrs	06 mtrs ✓	MR
2	<b>Number, Width, Type and Arrangement of Exits</b>			
A	Number of staircases			
a	Upper floor	02 nos	02 nos ✓	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.20 mtrs	1.20 mtrs each ✓	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	01 no	01 no ✓	MR
E	Width of corridor	1.5 mtrs	1.5 mtrs ✓	MR
F	Door size	1.0 mtr	1.0 mtr ✓	MR
3	<b>Compartmentation</b>			
a	Fire check door	N/A	N/A	N/A
b	Sealing of electrical shafts	Required	Sealed	MR
c	Fire rating of shaft door	N/A	N/A	N/A
d	Water curtain	N/A	N/A	N/A
e	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System</b>			
a	Basement	N/A	N/A	N/A
b	Upper floor	N/A	N/A	N/A

3


<b>5.</b>	<b>Fire Extinguisher</b>			
a	Total numbers	300 nos.	380 nos.	MR
b	Types	ABC, CO2 Water type	ABC, CO2 & Water type	MR
c	ISI marking	Required	Provided	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
a	Total numbers of each floor	02 nos	02 nos	MR
b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
c	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection &amp; Alarming System.</b>			
a	Type of detectors	Smoke	Provided	MR
b	Location of main panel	Security Room	Provided	MR
c	Location of repeater panel	Security Room	Reception	MR
d	Alternate source of power	Battery & DG Set	Provided	MR
e	Hooter's location	Staircase	Provided	MR
<b>8</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9</b>	<b>Public Address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
a	Basement	N/A	N/A	N/A
b	Upper floors	N/A	N/A	N/A
c	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
a	Size of riser/down-comer	100/200 mm	100/200 mm	MR
b	Number of hydrants per floor	02 nos	02 nos	MR
c	Hose Box	02 nos	02 nos	MR
<b>12</b>	<b>Yard Hydrants.</b>			
a	Total number of hydrants	20 nos	Provided	MR
b	Hose Box	20 nos	Provided	MR
<b>13</b>	<b>Pumping Arrangements.</b>			
<b>A</b>	<b>Ground Level</b>			
a	Discharge of main Pump	2850 LPM	2850 LPM	MR
b	Head of Main Pump	70 m	70 m	MR
c	Number of main pumps	01 no	01 no	MR
d	Jockey pump out put	180 LPM	180 LPM	MR
e	Jockey pump head	70 m	70 m	MR
f	Stand by pump out put	2850 LPM	2850 LPM	MR
g	Stand by pump head	70 m	70 m	MR
h	Auto starting /manual stopping	Required	Provided	MR
<b>B</b>	<b>Terrace Level</b>			
a	Discharge of pump	900 LPM	900 LPM	MR
b	Head of the Pump	40 mtrs	40 mtrs	MR
c	Power supply	Required	Provided	MR
d	Auto Starting of pump	Required	Provided	MR

M/25  
M/s Mother Dairy Fruits & Vegetable Private Limited located at Mother Dairy Patparganj,  
Delhi - 110092.

14	<b>Captive Water Storage for Fire Fighting</b>			
a	Underground tank capacity	2,00,000 ltrs	3,00,000 ltrs	MR
b	Draw-off connection	Required	Provided	MR
c	Fire service inlet	Required	Provided	MR
d	Access to tank	Accessible	Accessible	MR
e	Overhead Tank capacity	50,000 liters	50,000 liters	MR
15	<b>Exit Signage.</b>			
16	<b>Provision of Lifts.</b>			
a	Pressurization of Lift Shaft	NA	NA	NA
b	Pressurization of Lift lobby	NA	NA	NA
c	Communication in lift car	NA	NA	NA
d	Firemen's switch	NA	NA	NA
e	Lift Signage	Required	Provided	MR
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
a	Total area	NA	NA	NA
b	Location	NA	NA	NA
19	<b>Fire Control Room</b>			
a	Detector system panel	Required	Provided	MR
b	Flow switch panel	NA	NA	NA
c	PA system panel	Required	Provided	MR
d	Battery backup	Required	Provided	MR
e	Building Floor Plans	NA	NA	NA
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	Required	Provided	MR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of above deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC vide letter no. F6/DFS/MS/IndI/NDZ/2021/537 dated 29/10/2021 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

  
17/9/2024

Signature of the Inspecting Officer  
Name: - Yashwant Singh Meena  
Designation: - ADO (L.N)

~~DY. CFO/NDZ~~

~~King~~  
18/9/24

~~C.F.O.~~  
19/9/2024

~~Director~~  
20/9/24

Sir. F.I Letter is Autup for Sign. Please

~~Director~~  
25/9/24

  
24/9/2024