

C/37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

No.F6/DFS/MS/SZ/2024/School | 952 NEW DELHI

Dated: 27/09/2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Govt. Boys Senior Secondary School Located at Ramjas Lane-1, Karol Bagh, New Delhi – 110005. comprised of Ground + 01 Upper Floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2021/521 dated 23/07/2021. The premises was inspected by the officer concerned of this department on 20/09/2024 in the presence of Dr. Khaleeq Ahmed (Vice Principal) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B "Educational building" (Except Multi- purpose Hall) with effect from 27/09/2024 for a period of three years, subject to condition given below.

Issued on 27/09/2024... at New Delhi.

(Atul Garg)  
Director  
Delhi Fire Service  
O/c  
27/09/24

Copy to:

1. The Principal, Govt. Boys Senior Secondary School Located at Ramjas Lane-1, Karol Bagh, New Delhi – 110005.(School ID-2128014)
2. The, Directorate of Education Old Secretariat Delhi – 110054.

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/19

**INSPECTION REPORT**

1. Name & address of the building: Govt. Boys Senior Secondary School  
Located at Ramjas Lane-1, Karol Bagh, New Delhi – 110005.(School ID-2128014)
2. Type of Occupancy : Educational (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2021/521 dated 23/07/21
5. Fire Safety directives Letter No. : . Circular No. 3298-3398, dated 01/03/11
6. Date of inspection : 20/09/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Dr. Khaleeq Ahmed (Vice Principal)
9. Year of Construction : 2013-2014
10. Applicant's letter No. : Email, dated - 13/09/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/15, N/16 & N/17	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	3 Nos.	3 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m or less & 0.75m	1.25, 1.70 & 1.30m	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Old case	02 Nos.	MR
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	100cm	96cm,105cm Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA



N/20

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	14 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA

12/14

N/21

14	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/SZ/2021/521 dated 23/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
 Name: *Uday V Singh*  
 Designation: *AD/DW/N*

*[Signature]*  
 28/9/23

*CFO(SZ)*  
*[Signature]*  
 23/9/2023

*Director*  
*[Signature]*  
*AD/DW/N*