

c/49

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No.F6/DFS/MS/SZ2024/ Sch | 951

Dated: 27/09/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Boys Senior Secondary School Located at West Patel Nagar, New Delhi – 110008. having two blocks comprised of Ground + 01 Upper Floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2021/821 dated 07/10/2021. The premises was inspected by the officer concerned of this department on 20/09/2024 in the presence of Sh. Ram Kumar Singh Chauhan (Principal) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B “Educational building” with effect from 27/09/2024 for a period of **three years**, subject to condition given below.

Issued on 27/09/2024 at New Delhi.

(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Principal Govt. Boys Senior Secondary School Located at West Patel Nagar, New Delhi – 110008.(School ID-1516140)
2. The, Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form ‘K’ provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

11/35

INSPECTION REPORT

1. Name & address of the building: Govt. Boys Senior Secondary School
Located at West Patel Nagar, New Delhi – 110008.(School ID-1516140)
2. Type of Occupancy : Educational (02 blocks Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2021/821 dated 07/10/21
5. Fire Safety directives Letter No. : . Circular No. 3298-3398, dated 01/03/11
6. Date of inspection : 20/09/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. Ram Kumar Singh Chauhan (Principal)
9. Year of Construction : 2013-2014
10. Applicant's letter No. : Email, dated - 13/09/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/23, N/24 & N/25	Provided at site	Remarks MR/NMR
1	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	05(BL-B=03&BL-C=02)	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	BL B- 142, 150 cm (iron made) & 156cm, BL C- 2X162 cm	MR(Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	02	MR
	e. Width Of Corridor	1.5m	155cm& 170cm Provided	MR
	f. Door Size	100cm	102cm Provided	MR
3	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	Sealed	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	NA	NA	NA
		Required	Natural ventilation	MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	13 nos.	Provided	MR
		ABC & CO ₂	Provided	MR
		ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA

[Handwritten signature]

14	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	01 ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no. F6/DFS/MS/School/SZ/2021/821 dated 07/10/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: - Old Block comprised of ground floor only has been demarcated.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation MO/SWT

[Signature] 23/9/21
 CPO (S2)
 Director
 23/9/2021

[Signature]