

e64

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No: F.6/DFS/MS/SCHOOL/2024/ 960

Dated: 30 / 09 / 2024

**FIRE SAFETY CERTIFICATE**

Certified that the building of Kendriya Vidyalaya, located at Tagore Garden, New Delhi - 110027, building comprised of Ground plus two upper floors, was issued FSC vide Letter no:- F6/DFS/MS/SCHOOL/2021/WZ/169 dated 05/04/2017, Owned/occupied by Kendriya Vidyalaya. The premises was re-inspected by the officer concerned of this department on 20/09/2024 in the presence of Sh. Ashwani (Teacher) and observed that all the fire prevention and fire safety arrangements provided in the premises/building found in good working condition. The premises have deemed complied with the fire prevention and fire safety requirements in accordance with the DOE Circular No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011/NBC Part -IV and that the premises is fit for occupancy class "Educational" (Group -B) with effect from 30/09/24 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.conditions mention below.

Issued on 30/09/2024 at New Delhi by.

(Atul Garg)  
Director

Copy to:-

1. The Principal, Kendriya Vidyalaya, Tagore Garden, New Delhi - 110027.
2. The Director, Directorate of Education, Old secretariat, Delhi- 110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

*dcg*  
26/9/2024

## INSPECTION REPORT

1. Name & address of the building	Kendariya Vidyalaya located at Tagore Garden, New Delhi - 110027.
2. Type of Occupancy	Educational (Total 02 Blocks, ground + 2 upper floors)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/School/2021/WZ/169 dated 02/03/2021
5. Fire Safety directives letter No	DOE Circular 3298-3398 dated 01/03/2011
6. Date of inspection	20/09/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Ashwani (Teacher)
9. Year of Construction	1969 As per previous Insp. report dtd.- 12/02/2021
10. Applicant's letter No.	Outdoor diary no. dated 11/09/2024

**The Said school is running in total two blocks both are ground + two upper floors, was issued FSC by this department vide letter No. F6/DFS/MS/School/2021/WZ/169 dated 02/03/2021**

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	12m Provided	MR
	• Gate width	Accessible	05m Provided	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02 each block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	02 x 1.5m (Each Block)	BLK - A = 1 x 1.76m to 2.18m, 1 x 1.5 & BLK - B = 2 x 1.45m	MR Old case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01 at each block	Provided	MR
	f. Width of Corridor	1.5m	Provided (235cm)	MR
	g. Door Size	1m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	31 Nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	02 each Block	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	Provided	NA
9	<b>Public Address System.</b>	NA	Provided	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	Provided down comer	NA
	• Number of hydrants per floor	NA	Provided 02 each floor	NA
	• Hose Box	NA	Provided	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR
	➤ Auto Starting/ Manual stopping	NR	NR	NR
	➤ Pump House Access	NR	NR	NR
	• Terrace level			
	➤ Discharge of pump	2 X 450lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NR	NR	NR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	2 x 10,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

**Provision of Lifts.**

MR  
MR  
R

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	NA	NA	NA
18	<b>Refuge Area.</b>			
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no.F6/DFS/MS/School/2017/WZ/169, Dated-02/03/2021, renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~Dy CFO (W12)~~

~~Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)~~

Sl. No. 123  
Dated: 23/09/2024

~~dy~~  
23/9/2024

~~CFO~~  
24/9/2024

~~Director~~  
25/9/24

~~Director~~  
~~Signature~~

Sir, F.T is put up for your kind personal signature pls.

~~Signature~~  
26/9/2024