

0/24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2024/ 953

Dated: 27/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Vidyalaya, K-2 Block, Mangol Puri, Delhi-110083, (School Id-1412082), comprised of 05 blocks, Ground + One upper floor owned/occupied by North Sarvodaya Vidyalaya, was issued fire safety certificate by this department vide letter no. F.6/DFS/MS/School/WZ/2021/704 dated 03.09.2021. The premises was re-inspected by the officer concerned of this department on 18.09.2024 in the presence of Sh. Dhara Singh (Principal) and observed that all the fire prevention and fire safety-arrangements as provided in the premise found in good working condition. The premise have deemed complied with the requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "B" Educational Buildings with effect from 27/09/2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 27/09/2024 at New Delhi by


(Atul Garg)
DIRECTOR
Ph; 011-23414000



Copy to:

1. The Principal, Sarvodaya Vidyalaya, K-2 Block, Mangol Puri, Delhi-110083.
2. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'j' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms

INSPECTION REPORT

| 1. Name & address of the building | Sarvodaya Vidyalaya, K-2 Block, Mangol Puri, Delhi-110083.(School Id-1412082) | | | |
|--|---|--|---|----------------------------|
| 2. Type of Occupancy | Educational | | | |
| 3. Type of Case | Renewal (05 Blocks, Ground + 01 upper floors) | | | |
| 4. Details of Previous NOC | F.6/DFS/MS/School/WZ/2021/704 dated 03.09.2021. | | | |
| 5. Fire Safety directives letter No | Director of Education Cir. dated 01.03.2011. | | | |
| 6. Date of inspection | 18.09.2024. | | | |
| 7. Name of Inspecting Officer | Sh. Ajay Kumar Sharma (ADO Rohini) | | | |
| 8. Name and designation of officers From the building side | Mr. Dhara Singh (Principal) | | | |
| 9. Year of Construction | 2000 & 2001 | | | |
| 10. Applicant's letter No. | OD No.5209 dated 13.08.2024. | | | |
| S. No | Minimum Standards on fire prevention and fire safety U/R 33 | DOE Cir. 01.03.2011 Requirement | Provided at site | Remarks MR/NMR |
| 1. | Access to building | | | |
| | • Road width | Accessible | Accessible | MR |
| | • Gate width | Directly Accessible | Directly Accessible | MR |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | • Upper Floors | A Block-01 S/C B Block-01 S/C C Block-01 S/C D Block-01 S/C E Block-01 S/C | A Block-03S/C B Block-02 S/C C Block-02 S/C D Block-01 S/C E Block-02 S/C | MR MR MR MR MR |
| | • Basements | -NA- | -NA- | -NA- |
| | b. Width of staircases | | | |
| | • Upper Floor | A Block-1.5m B Block-1.5m C Block-1.5m D Block-1.5m E Block-1.5m | A -1.45 & 2 x 1.70m B- 1.50 & 1.70m C- 1.45 & 1.70m D- 1.5m E- 1.47 & 1.70m | MR MR MR MR MR |
| | • Basements | -NA- | -NA- | -NA- |
| | c. Protection of exits | | | |
| | • Fire check door | -NA- | -NA- | -NA- |
| | • Pressurization | -NA- | -NA- | -NA- |
| | d. No. of continuous staircases to terrace | -NA- | -NA- | -NA- |
| | e. Width of Corridor | -NA- | -NA- | -NA- |
| | f. Door Size | -NA- | -NA- | -NA- |
| 3. | Compartmentation | | | |
| | • Fire check door | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts | -NA- | -NA- | -NA- |
| | • Fire Rating of shaft door | -NA- | -NA- | -NA- |
| | • Water Curtain | -NA- | -NA- | -NA- |
| | • Fire Dampers | -NA- | -NA- | -NA- |
| 4. | Smoke Management System | | | |
| | a) Basements | -NA- | -NA- | -NA- |
| | b) Upper floors | -NA- | -NA- | -NA- |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 18nos. | Provided | MR |
| | • Types | ABC/CO2 | ABC/Co2 | MR |
| | • IS marking | ISI marked | Yes | MR |

✍️ ✍️

| | | | | |
|------------|---|------|------|------|
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | -NA- | -NA- | -NA- |
| | • Length of hose reel hose | -NA- | -NA- | -NA- |
| | • Nozzle diameter | -NA- | -NA- | -NA- |
| 7. | Automatic fire detection and alarming system | | | |
| | a) Type of detectors | -NA- | -NA- | -NA- |
| | b) Location of Main Panel | -NA- | -NA- | -NA- |
| | c) Location of Repeater Panel | -NA- | -NA- | -NA- |
| | d) Alternate source of power | -NA- | -NA- | -NA- |
| | e) Hooters' Location | -NA- | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | -NA- | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | -NA- | -NA- | -NA- |
| | • Ground & Upper Floors | -NA- | -NA- | -NA- |
| | • Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | -NA- | -NA- | -NA- |
| | • Number of hydrants per floor | -NA- | -NA- | -NA- |
| | • Hose Box | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | -NA- | -NA- | -NA- |
| | • Hose Box | -NA- | -NA- | -NA- |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | -NA- | -NA- | -NA- |
| | ➤ Discharge of main Pump | -NA- | -NA- | -NA- |
| | ➤ Head of Main pump | -NA- | -NA- | -NA- |
| | ➤ Number of main pumps | -NA- | -NA- | -NA- |
| | ➤ Jockey Pump out put | -NA- | -NA- | -NA- |
| | ➤ Jockey pump head | -NA- | -NA- | -NA- |
| | ➤ Standby Pump out put | -NA- | -NA- | -NA- |
| | ➤ Standby Pump Head | -NA- | -NA- | -NA- |
| | ➤ Auto Starting/Manual Stopping | -NA- | -NA- | -NA- |
| | ➤ Pump House Access | -NA- | -NA- | -NA- |
| | Terrace level | | | |
| | ➤ Discharge of pump | -NA- | -NA- | -NA- |
| | ➤ Head of the pump | -NA- | -NA- | -NA- |
| | ➤ Power Supply | -NA- | -NA- | -NA- |
| | ➤ Auto Starting of pump | -NA- | -NA- | -NA- |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | -NA- | -NA- | -NA- |
| | ➤ Draw-off connection | -NA- | -NA- | -NA- |
| | ➤ Fire service inlet | -NA- | -NA- | -NA- |
| | ➤ Access to tank | -NA- | -NA- | -NA- |
| | • Overhead Tank capacity | -NA- | -NA- | -NA- |
| 15. | Exit Signage. | -NA- | -NA- | -NA- |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | -NA- | -NA- | -NA- |
| | • Pressurization of Lift lobby | -NA- | -NA- | -NA- |

| | | | | |
|-----|---|------|------|------|
| | • Communication In lift Car | -NA- | -NA- | -NA- |
| | • Fireman's Grounding Switch | -NA- | -NA- | -NA- |
| | • Lift Signage | -NA- | -NA- | -NA- |
| 17. | Standby power supply | -NA- | -NA- | -NA- |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | -NA- | -NA- | -NA- |
| | ➤ Location | -NA- | -NA- | -NA- |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | -NA- | -NA- | -NA- |
| | • Flow Switch Panel | -NA- | -NA- | -NA- |
| | • PA System Panel | -NA- | -NA- | -NA- |
| | • Battery backup | -NA- | -NA- | -NA- |
| | • Building Floor Plans | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | -NA- | -NA- | -NA- |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/School/WZ/2021/704 dated 03.09.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Ajay Kumar Sharma
18/9/24

Signature of the Inspecting Officer
Name Ajay Kumar Sharma
Designation ADO(Rohini)

D.B Mukherjee
DO (NW)

Ajay
20/09/2024

Dy CFO (WZ)

Ajay
23/9

488-Atk
23.09.24

CFO
23/9/2024

Director
24/9/24

Ajay

AT letter is put up for kind perusal and signature please.

Director

M

Ajay
23/9/24