

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/959

Dated: 30/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Sarvodaya Vidyalaya No-1**, located at **Sector-2, R. K Puram, New Delhi- 110022** comprised of Ground + Two upper floor (01 Block) & Ground + One upper floor (01 Block) both block are interconnected owner/ occupied by Directorate of Education was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2021/SZ/550 Dated 28/07/2021. The said premises was re-inspected by officer concerned of this department on 24/08/2024 in presence of Ms. Poonam Sehgal (Principal) of the school and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "**Educational Building**" Group - B with effect from 30/09/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 30/09/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Sarvodaya Vidyalaya No-1, at Sector-2, R. K Puram, New Delhi- 22
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-54

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This certificate cannot be treated as regularization of unauthorized construction, if any.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

| | | | | |
|-------|-------------------------------------------------------------|-------------------------------------------------------------------------------|------------------------------------|----------------|
| 1 | Name & Address of the Building | Sarvodaya Vidyalaya No 1, Sector 2, R. K Puram, New Delhi-110022 (ID 1719069) | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | Ground + Two Upper Floor (01 block) & Ground + One (01 Block) interconnected | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DPS/MS/School/2021/SZ/550 Dt. 28/07/2021 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 24/09/2024 | | |
| 8 | Name of the Inspecting Officers | Sh. Rajesh Kumar, ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Ms. Poonam Sehgal (Principal) | | |
| 10 | Year of construction | 1962 & 2010 | | |
| 11 | Applicant letter No. | Email dated 27/08/2024 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC Requirement | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | Required | 6 mtr | MR |
| | • Gate width | 5 mtr | 5 mtr | MR |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | 03 Nos | 03 Nos | MR |
| | ➤ Basement floor. | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.50 mtr | G + 2- 1.62 m each G + 1- 1.5 m | MR MR |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e) Width of corridor | 1.50 m | 1.50 m | MR |
| | f) Door size | 1 mtr | 1 mtr | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | -NA- | -NA- | -NA- |
| | • Upper floors | -NA- | -NA- | -NA- |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | 18 no's | 23 Nos | MR |
| | • Types | ABC / co2 | ABC & co2 Type | MR |
| | • ISI Marking | ISI mark | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | 02 No's | Provided | MR |
| | • Length of hose-reel hose. | 30 m | 30 m | MR |
| | • Nozzle Diameter | 5 mm | 5 mm | MR |
| 7 | Automatic fire detection & alarming system. | | | |

| | | | | |
|-----|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|----------|------|
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location | -NA- | -NA- | -NA- |
| 8. | MOEFA | -NA- | -NA- | -NA- |
| 9. | Public Address System | -NA- | NA | -NA- |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | <ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. | -NA- | -NA- | -NA- |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> Total number of hydrants. Hose box. | -NA- | -NA- | -NA- |
| 13. | Pumping arrangements. | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | 450 LPM | Provided | MR |
| | | 40 m | Provided | MR |
| | | Required | Provided | MR |
| | | Required | Provided | MR |
| 14. | Captive water storage for fire fighting. | | | |
| | <ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | 10,000 ltrs | Provided | MR |
| | | Required | Provided | MR |
| 15. | Exit Signage. | | | |
| 16. | Provision of Lifts. | | | |
| | <ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 17. | Standby Power Supply | | | |
| 18. | Refuge Area | | | |
| | <ul style="list-style-type: none"> Total area Location | -NA- | -NA- | -NA- |
| | | -NA- | -NA- | -NA- |
| 19. | Fire Control Room. | | | |
| | <ul style="list-style-type: none"> Detector system panel. | -NA- | -NA- | -NA- |

| | | | | |
|-----|----------------------------------------------------------------------------|------|------|------|
| | • Flow switch panel. | -NA- | -NA- | -NA- |
| | • PA system panel. | -NA- | -NA- | -NA- |
| | • Battery backup. | -NA- | -NA- | -NA- |
| | • Building floor plan. | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | -NA- | -NA- | -NA- |

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 493 dated 02/08/2024.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2021/SZ/550 Dt. 28/07/2021, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please

[Handwritten Signature]
24/9/2024

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SO)

[Handwritten mark]

[Handwritten signature]
24/9/2024

[Handwritten signature]
25/9/24

As approved, F.T. letter is put up for your signature pl

[Handwritten signature]
Director

[Handwritten signature]
26/9/2024