

C/37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

No.F6/DFS/MS/SZ/2024/School | 952 NEW DELHI

Dated: 27/09/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Boys Senior Secondary School Located at Ramjas Lane-1, Karol Bagh, New Delhi – 110005. comprised of Ground + 01 Upper Floors was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2021/521 dated 23/07/2021. The premises was inspected by the officer concerned of this department on 20/09/2024 in the presence of Dr. Khaleeq Ahmed (Vice Principal) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 Dated 01/03/2011 issued by the Director of Education and that the building is fit for occupancy class B "Educational building" (Except Multi- purpose Hall) with effect from 27/09/2024 for a period of three years, subject to condition given below.

Issued on 27/09/2024... at New Delhi.

(Atul Garg)
Director
Delhi Fire Service
O/c
27/09/24

Copy to:

1. The Principal, Govt. Boys Senior Secondary School Located at Ramjas Lane-1, Karol Bagh, New Delhi – 110005.(School ID-2128014)
2. The, Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/19

INSPECTION REPORT

1. Name & address of the building: Govt. Boys Senior Secondary School
Located at Ramjas Lane-1, Karol Bagh, New Delhi – 110005.(School ID-2128014)
2. Type of Occupancy : Educational (Ground + 01 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/SZ/2021/521 dated 23/07/21
5. Fire Safety directives Letter No. : . Circular No. 3298-3398, dated 01/03/11
6. Date of inspection : 20/09/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Dr. Khaleeq Ahmed (Vice Principal)
9. Year of Construction : 2013-2014
10. Applicant's letter No. : Email, dated - 13/09/2024

| S No | Minimum standards on fire prevention and fire safety U/R 33 | As per N/15, N/16 & N/17 | Provided at site | Remarks MR/NMR |
|------|---|--------------------------|---------------------|--------------------|
| 1. | Access of building | | | |
| | • Road width | 06 mtrs | Provided | MR |
| | • Gate width | 4.5m | Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 3 Nos. | 3 Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5m or less & 0.75m | 1.25, 1.70 & 1.30m | MR(Being old case) |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | Old case | 02 Nos. | MR |
| | e. Width Of Corridor | 1.5m | Provided | MR |
| | f. Door Size | 100cm | 96cm,105cm Provided | MR |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |

N/20

| | | | | | |
|----|--|-----------------------|---------------------|----|----|
| 4. | Smoke managements System | | | | |
| | • Basements | NA | NA | NA | NA |
| | • Upper floors | Required | Natural ventilation | MR | |
| 5. | Fire Extinguishers | | | | |
| | • Total numbers | 14 nos. | Provided | MR | |
| | • Types | ABC & CO ₂ | Provided | MR | |
| | • IS marking | ISI marked | Provided | MR | |
| 6. | First – Aid Hose Reels | | | | |
| | • Total numbers on each floor | NA | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | | |
| | • Type of detectors | NA | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA | NA |
| 10 | Automatic Sprinkler System | | | | |
| | • Basements | NA | NA | NA | NA |
| | • Upper Floor | NA | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA | NA |
| 11 | Internal Hydrants: | | | | |
| | • Size of riser/down- comer | NA | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA | NA |
| | • Hose Box | NA | NA | NA | NA |
| 12 | Yard Hydrants | | | | |
| | • Total number of hydrants | NA | NA | NA | NA |
| | • Hose Box | NA | NA | NA | NA |
| 13 | Pumping Arrangements: | | | | |
| | • Ground Level | NA | NA | NA | NA |
| | • Discharge of main pump | NA | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA | NA |
| | • Terrace level | | | | |
| | ➤ Discharge of pump | NA | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA | NA |
| | ➤ Power supply | NA | NA | NA | NA |
| | ➤ Auto starting of pump | NA | NA | NA | NA |

| | | | | |
|----|--|----------|----------|----|
| 14 | Captive water Storage for fire fighting: | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15 | Exit Signage | Required | Provided | MR |
| 16 | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17 | Standby power supply | NA | NA | NA |
| 18 | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19 | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/SZ/2021/521 dated 23/07/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name *Uday V Singh*
 Designation *AD/DW*

[Signature]
 28/9/21

CFO(S2)
[Signature]
 23/9/2021

Director
[Signature]
[Signature]