

c/33

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F 6/DFS/MS/2024/School/WZ | 954

Dated: 27/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **M. C. Primary School, G-Block, Sector-16, Rohini, Delhi-110089** comprised of **02 Blocks(A block Ground floor & B block Ground + One upper floor)** owned/occupied by **M. C. Primary School** was granted FSC by this department vide letter No. **F 6/DFS/MS/2021/School/WZ/592** dated **10.08.2021**. The premises was re-inspected by the officer concerned of this department on **06.09.2024** in the presence of **Mrs. Sunanda Vats (In-charge)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from 27/09/2024 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 27/09/2024 at New Delhi

(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, North MCD, Civic Center, New Delhi
2. The Principal, M. C. Primary School, G-Block, Sector-16, Rohini, Delhi-110089.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building : M. C. Primary School, G-Block, Sector-16, Rohini, Delhi-110089.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Two Blocks, Ground & Ground + 01 upper floor)
4. Details of Previous NOC : F.6/DFS/MS/2021/School/WZ/592 dated 10.08.2021
5. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
6. Date of inspection : 06.09.2024
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Mrs. Sunanda Vats (In-charge)
9. Year of Construction : 2003
10. Applicant's letter No. : O.D No.4915 dated 05.08.2024.

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Cir Director of Education | Provided at site | Remarks MR/NMR |
|-----------|---|---------------------------|--------------------|----------------|
| 1. | Access to building | | | |
| | • Road width | Accessible | Accessible | MR |
| | • Gate width | Accessible | Accessible | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | d. Number of staircases | | | |
| | • Upper Floors | 01 | 01 | MR |
| | • Basements | NA | NA | NA |
| | e. Width of staircases | | | |
| | • Upper Floor | 1.5m | 2.10m | MR |
| | • Basements | NA | NA | NA |
| | f. Protection of exits | | | |
| | Fire check door | NA | NA | NA |
| | • Pressurization | NA | NA | NA |
| | d. No. of continuous staircases to terrace | 01 | 01 | MR |
| | e. Width of Corridor | NA | NA | NA |
| | f. Door Size | NA | NA | NA |
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke Management System | | | |
| | • Basements | 30 a/c per hour | NA | NA |
| | • Upper floors | 12 a/c per hour | Natural ventilated | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 06nos. | 08nos. | MR |
| | • Types | ABC/CO2 | ABC-08 | MR |
| | • IS marking | ISI marked | Yes | MR |
| 6. | First-Aid Hose Reels | | | |
| | • Total numbers on each floor | NA | NA | NA |
| | • Length of hose reel hose | NA | NA | NA |
| | • Nozzle diameter | NA | NA | NA |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |

(Handwritten signature)

A/25

| | | | | |
|-----|---|----|----|----|
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | NA | NA | NA |
| | • Basement | NA | NA | NA |
| | • Ground & Upper Floors | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13. | Pumping Arrangements | | | |
| | • Ground Level | NA | NA | NA |
| | ➤ Discharge of main Pump | NA | NA | NA |
| | ➤ Head of Main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey Pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Starting/Manual Stopping | NA | NA | NA |
| | ➤ Pump House Access | NA | NA | NA |
| | • Terrace level | | | |
| | ➤ Discharge of pump | NA | NA | NA |
| | ➤ Head of the pump | NA | NA | NA |
| | ➤ Power Supply | NA | NA | NA |
| | ➤ Auto Starting of pump | NA | NA | NA |
| 14. | Captive Water Storage for fire fighting | | | |
| | • Underground tank capacity | NA | NA | NA |
| | ➤ Draw-off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | NA | NA | NA |
| 15. | Exit Signage. | NA | NA | NA |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Battery backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |

2

H/26

Special Fire Protection System for
Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/2021/School/WZ/592 dated 10.08.2021** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
Name **Ajay Kumar Sharma**
Designation **ADO(Rohini)**

DO (NW) ~~20/09/2024~~

~~Dy CFO (WZ)~~

~~SD (NW)
10/9/24~~

~~23/9~~

~~CA
23/9/2024~~

~~Director
21/9/24~~

~~Amal~~

Fr letter to put up for kind perusal
and signature please.

~~Director~~

~~Amal
25/9/24~~