

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001
 No.F6/DFS/MS/2024/ School/ NDZ/ 958 Dated:..30/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Navyug Primary School located at Pataudi House, New Delhi comprises of Ground + 01 Upper floor only (below 09 meter in height, was earlier granted FSC by this department vide letter No. F6/DFS/MS/2021/School/NDZ/427 dated 05/07/2021. Now, the premises was re-inspected by the officers concerned of this department on 19-09-2024 in the presence of Sh. Mahendar Shokeen (Fire officer NDMC) and found that school has deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from 30/09/2024 for a period of three years subject to compliance of the conditions mentioned below:

Issued on ...30/09/2024... at New Delhi by.

(Atul Garg)
 DIRECTOR
 Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, Navyug Primary School at Pataudi House, New Delhi.
2. Sh. N.K Gaur, Fire Officer, NDMC, Palika Kendra, New Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape such as exits, staircase, etc shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.

N/18
INSPECTION REPORT

1. Name & address of the building:- Navyug Primary School at Pataudi House, New Delhi
2. Type of occupancy:- Educational Group B-I, Gr.+01 Upper Floor
3. Type of case:- Renewal
4. Details of previous NOC:- No.F6/DFS/MS/2021/School/NDZ/427 dated 05/07/2021.
5. Fire safety directives No.- N/A
6. Date of inspection:- 19/09/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer From the building side:- Sh. Mahendar Shokeen (Fire officer NDMC)
9. Year of construction:- 1993-94
10. Applicant's letter No:- mail id no.<Narender kumar Gaur">
<fo@ndmc.gov.in> dated 23.08.2024

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement /Exiting arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Accessible	06 mtr. ✓	MR
	2) Gate width	Accessible	Provided	MR
	3)Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25mtr	Iron s/c 1.27 mtr., RCC s/c 1.25 to 1.30 mtr. ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	N/A	N/A
3.	Compartmentation		1.25 mtr. ✓	MR
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System		N/A	N/A
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers		N/A	N/A

2/9

	1) Total numbers	04 Nos.	12 Nos. /	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	02 /	N/A
	2) Length of hose reel hose	N/A	30 mtr.	N/A
	3) Nozzle diameter	N/A	05 mm	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	Provided	N/A
	b) Head of pump	N/A	40 mtr. /	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of	N/A	Provided	N/A

	pump			
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	2500 ltr.	N/A
15.	Exit Signage.	Required	Provided /	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO2			MR

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the Director Education Circular, the FSC issued vide letter No. F6/DFS/MS/2021/School/NDZ/427 dated 05/07/2021, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

[Signature]
23/9/24

Name :- Sh. Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer

[Signature]
23/9/24

Name :- Sh. Ravinder Singh
Designation : ADO (CC)

[Signature]
C.F.O.

[Signature]
24/09/24

[Signature]
25/9/2024

[Signature]
25/9/24

[Signature]