

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6/DFS/MS/2024/School/WZ/ 989

Dated: 07/10/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **C. M. Model School, J-1, Budh Vihar, Phase-II, Near Sec-24, Rohini, Delhi-110085**, comprised of **Ground + One upper floor** owned/occupied by **C. M. Model School** was granted FSC by this department vide letter No. **F.6/DFS/MS/2021/School/WZ/612** dated **13.08.2021**. The premises was re-inspected by the officer concerned of this department on **18.09.2024** in the presence of **Miss. Sudha Tripathi (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy **Group 'B' Educational** with effect from 07/10/2024 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 07/10/2024 at New Delhi

  
**(Atul Garg)**  
**DIRECTOR**  
**Ph: 011-23414000**

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, C. M. Model School, J-1, Budh Vihar, Phase-II, Near Sec-24, Rohini, Delhi-110085

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://www.delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

**INSPECTION REPORT**

1. Name & address of the building	C. M. Model School, J-1, Budh Vihar, Phase-II, Near Sec-24, Rohini, Delhi-110085.			
2. Type of Occupancy	Educational			
3. Type of Case	Renewal ( <b>Ground + 01 upper floor</b> )			
4. Details of Previous NOC	F.6/DFS/MS/2021/School/WZ/612 dated 13.08.2021.			
5. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.			
6. Date of inspection	18.09.2024			
7. Name of Inspecting Officer	A.K.Sharma ADO(Rohini)			
8. Name and designation of officers From the building side	Mrs. Sudha Tripathi (Principal)			
9. Year of Construction	2008 & 2017			
10. Applicant's letter No.	OD No.5060 dated 08.08.2024			
<b>S. No</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>D.O.E Cir. dated 01.03.2011</b>	<b>Provided at site</b>	<b>Remarks MR/NMR</b>
1.	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	01nos	02nos.	MR
	• Basements	-NA-	-NA-	-NA-
	<b>b. Width of staircases</b>			
	• Upper Floor	1.5m	Provided	MR
	• Basements	-NA-	-NA-	-NA-
	<b>c. Protection of exits</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	<b>d. No. of continuous staircases to terrace</b>	01nos.	Provided	MR
	<b>e. Width of Corridor</b>	Required	Provided	MR
	<b>f. Door Size</b>	-NA-	-NA-	-NA-
3.	<b>Compartmentation</b>			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire Rating of shaft door	-NA-	-NA-	-NA-
	• Water Curtain	-NA-	-NA-	-NA-
	• Fire Dampers	-NA-	-NA-	-NA-
4.	<b>Smoke Management System</b>			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	-NA-	-NA-	-NA-
5.	<b>Fire Extinguishers</b>			
	• Total numbers	09nos.	10nos.	MR
	• Types	ABC/CO2	ABC-10	MR
	• IS marking	ISI marked	Yes	MR
6.	<b>First-Aid Hose Reels</b>			
	• Total numbers on each floor	-NA-	-NA-	-NA-
	• Length of hose reel hose	-NA-	-NA-	-NA-
	• Nozzle diameter	-NA-	-NA-	-NA-



7.	<b>Automatic fire detection and alarming system</b>	-NA-	-NA-	-NA-
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	-NA-	-NA-
9.	<b>Public Address System</b>			
10.	<b>Automatic Sprinkler System</b>	-NA-	-NA-	-NA-
	• Basement	-NA-	-NA-	-NA-
	• Ground & Upper Floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>	-NA-	-NA-	-NA-
	• Size of riser/down-comer	-NA-	-NA-	-NA-
	• Number of hydrants per floor	-NA-	-NA-	-NA-
	• Hose Box	-		
12.	<b>Yard Hydrants</b>	-NA-	-NA-	-NA-
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose Box			
13.	<b>Pumping Arrangements</b>	-NA-	-NA-	-NA-
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	<b>Captive Water Storage for fire fighting</b>	-NA-	-NA-	-NA-
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	-NA-	-NA-	-NA-
		Required	Provided	MR
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>	-NA-	-NA-	-NA-
	• Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	• Pressurization of Lift lobby	-NA-	-NA-	-NA-
	• Communication In lift Car	-NA-	-NA-	-NA-
	• Fireman's Grounding Switch	-NA-	-NA-	-NA-
	• Lift Signage	-NA-	-NA-	-NA-

CA

Standby power supply	-NA-	-NA-	-NA-
Refuge Area.			
> Total Area	-NA-	-NA-	-NA-
> Location	-NA-	-NA-	-NA-
19. Fire Control Room			
• Detector System Panel	-NA-	-NA-	-NA-
• Flow Switch Panel	-NA-	-NA-	-NA-
• PA System Panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building Floor Plans	-NA-	-NA-	-NA-
20. Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

The fire protection systems provided in the building were test checked and tested randomly and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in Director of Education Circular, the FSC issued vide letter no. F.6/DFS/MS/2021/School/WZ/612 dated 13.08.2021 is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

*(Signature)*

Signature of the Inspecting Officer  
 Name           Ajay Kumar Sharma  
 Designation   ADO(Rohini)

D.B Mukherjee  
 DO (NW)

*(Signature)*  
 24/09/2024

*(Signature)*  
 24/09/2023

*(Signature)*  
 26/8

DCFO/535/N/10  
 D.O. 26/09/24

*(Signature)*  
 Cfo  
 27/9/2021

*(Signature)*  
 Director

*(Signature)*  
 Ajay Kumar

FT letter letter to put up for kind  
 Personal and signature please.

*(Signature)*  
 Director

*(Signature)*  
 4/10/24