

c 20

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2024/ 316

Dated: 03/10/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Coffee Day Global Ltd.(cafe coffee day) ,C-14, First Floor, Inner Circle, Connaught Place, New Delhi – 110001, in building comprised of Gr. + 2 Upper floors, and restaurant is running at first floor only. The premises was inspected by the officers concerned of this department on 17/09/2024 in the presence of Mr. Nadeem, Manager and found that the said restaurant has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant premises is fit for occupancy class **Assembly occupancy -Group D restaurant at first floor only** and valid up to three year from the date of issue in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued... 03/10/2024 at New Delhi by.

(Atul Gang)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC Palika Kendra , New Delhi: to kindly ensure the occupancy as above & deviation w.r.t to construction if any.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi ID no. ID No. 2024090713914 dated 07/09/24.
3. The Manager, Coffee Day Global Ltd.,C-14, First Floor, Inner Circle, Connaught Place, New Delhi – 110001.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. This FSC is valid for restaurant at First floor only.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Basement shall not be used for any purpose.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

N/C

INSPECTION REPORT

1. Name & address of the building:- M/s Coffee Day Global Ltd., C-14, First Floor, Inner Circle, Connaught Place, New Delhi - 110001. Gr. + 02 Upper floors.
2. Type of occupancy:- Assembly occupancy Group-D
Running at first floor.
3. Type of case:- New case
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 17/09/24
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal (DO/CD)
8. Name & designation of officer
From the building side:- Mr. Nadeem, Manager
heritage building
9. Year of construction:- ID No 2024090713914 dated 07/09/24.
10. Applicant's letter No:-

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirements/ | Provided at site | Remarks MR/NMR |
|-----------|-------------------------------------------------------------|-------------------|------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 06 meter | 12 mtr. | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | 02 | 02 | MR |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | 1.0 & 1.5M | 1.0 & 1.5m | MR |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | | | |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 1 mtr. & 1.5 mtr. | provided | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | N/A | N/A | N/A |
| | 2) Upper floors | 12 ACPH | Exhaust fan | MR |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | 02 Nos. | 02 Nos. | MR |
| | 2) Types | ABC & CO2 | ABC & CO2 | MR |

| | | Required | Provided | MR |
|------------|-------------------------------------------------------|----------|----------|-----|
| | 3) ISI marking | | | |
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | 01 | 01 | MR |
| | 2) Length of hose reel hose | 30 mtr. | 30 mtr. | MR |
| | 3) Nozzle diameter | 05 mm | 05 mm | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | provided | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | 100mm | 100mm | MR |
| | 2) Number of hydrants per floor | 01nos | 01nos | MR |
| | 3) Hose box | 01 nos | 01 nos | MR |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | 450 LPM | 450 LPM | MR |
| | b) Head of pump | 40 mtr. | 40 mtr. | MR |
| | c) Power supply | Required | Provided | MR |
| | d) Auto starting of pump | Required | Provided | MR |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |

N18

| | | | | |
|-----|-------------------------------------------------------------------------------|-------------|------------|-----|
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 20,000 ltr. | Provided / | MR |
| 15. | Exit Signage. | Required | Provided / | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | NA |

The fire protection systems provided in the said building were randomly tested, checked and found functional at the time of inspection

Further, the said cafe coffee day is situated at first floor and operating since 2013 as per health department (NDMC) license No. 1955 and existing one staircase of 01 meter width is serving two restaurant i.e the said café coffee day & Open house Bar & kitchen in adjacent building. The open house bar & kitchen has already issued FSC by this department vide letter no. F6/DFS/EH/NDZ/2024/198 dated 24.06.2024. Further, alternate staircase has been made of iron steel of 1.5 meter width in the back side. Accordingly, if agreed, we may consider the existing staircase of 1.0 meter as it is serving to this restaurant also.

In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may issue FSC to said restaurant. Accordingly, DFA is prepared and put up for kind perusal and sig. pl.

Signature of the Inspecting Officer

[Handwritten Signature]
25/9/24

Name:- Rajinder Atwal
Designation:-DO(CD)

Signature of the Inspecting Officer

[Handwritten Signature]
25/9/24

Name:- Sh. Ravinder Singh
Designation:- ADO (CC)

[Handwritten Signature]
27/9/24

[Handwritten Signature]
26/9/24

C.F.O. *[Handwritten Signature]*
27/9/24

Director *[Handwritten Signature]*
27/9/24

[Handwritten Signature]