

c-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SCHOOL/SZ/2024/966

Dated: 03/10/2024

FIRE SAFETY CERTIFICATE

Certified that the building of Manav Sthali Global School Located at Double Storey, New Rajinder Nagar, New Delhi - 110060 comprised of ground + 2 upper floors was issued Fire Safety Certificate vide Letter No: F.6/DFS/MS/School/2021/SZ/760 dated 21/09/2021. The premises was re inspected by the officer concerned of this department on 17/09/2024 in the presence of Ms. Veena Ramtri (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance Delhi Fire Service Rules 2010 under Delhi Fire Service Act 2007 and that the premises is fit for occupancy class "Educational" Group B with effect from 03/10/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/10/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The Directorate of Education Old Secretariat Delhi – 110054.
2. The Principal, Manav Sthali Global School Located at Double Storey, New Rajinder Nagar, New Delhi - 110060.

Condition for the validity of fire safety certificate:-

1. The staircase at terrace level shall be kept open & free from lock and key & all the exit shall be clear from any obstruction otherwise the FSC shall be null & void
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/28

INSPECTION REPORT

1. Name & address of the building: Manav Sthali Global School Located at Double Storey, New Rajinder Nagar, New Delhi - 110060.
2. Type of Occupancy : Educational (Ground + 02 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F.6/DFS/MS/School/2021/SZ/760 dated 21/09/21
5. Fire Safety directives Letter No. : . NA
6. Date of inspection : 17/09/2024
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer
from the building side : Ms. Veena Ramtri (Principal)
9. Year of Construction : Before 1985
10. Applicant's letter No. : MSGS/DS/2024/546 date 29/08/2024

No. of Students=386
No. of class rooms=22
Plot area=1990 Sq.yds
Covered area=1678sq.yds

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/20, N/21 & N/22	Provided at site	Remarks MR/NMR
1.	Access of building	06 mtrs	Provided	MR
	• Road width	4.5mtrs	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 No's	02 No's	MR
	• Upper floors	NA	NA	NA
	• Basements			
	b. Width of staircases	1.5 mtr or less & 0.75m	1.20m to 1.5m	MR(Being old case)
	• Upper floors	NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	01	01	MR
	d. No of continuous staircase to terrace	150 cms	Provided	MR
	e. Width Of Corridor	100cm	Provided	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
5.	Fire Extinguishers			

N/29

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	16 Nos. ABC & CO ₂ ISI marked	Provided Co ₂ & ABC Provided	MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 No 30 m 05mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA	NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10,000 ltr	NA NA NA NA Provided	NA NA NA NA MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter F.6/DFS/MS/School/2021/SZ/760 dated 21/09/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended. If approved FSC may be issued.

Signature of the Inspecting Officer:

Name Uday Vir Singh

Designation ASO/School

Uday Vir Singh
21/9/24

[Signature]
20/9/24

[Signature]
21/9/2024
CFO(S2)
Director

[Signature]
29/9/22

in
Sir AP letter is put up for sig
DIRECTOR
[Signature]
25/9/24