

C-31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2024/ 595

Dated: 30/09/2024

FIRE SAFETY CERTIFICATE

Certified that the Mandi House, Underground Metro Station at New Delhi, was earlier granted FSC by this department vide letter F6/DFS/MS/DMRC/2006/3432 dated 24.11.2006, Now, the premises was re-inspected by the officer concerned of this department on 19-09-2024 in the presence of Sh. Omkara & Sh. Ravinder (Fire officer) and found that the said Metro Station have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building** with effect from 30/09/2024...2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/09/2024..... at New Delhi by.

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

CGM (E&M) DMRC,
Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi.

ConditionS for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned. Basement shall not be used for any purpose.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Property Development Area at Metro station has already been issued FSC for Business occupancy.
10. The flammable material use for interior decoration, if any, shall strictly be prohibited.

INSPECTION REPORT

1. Name & address of the building : **Mandi house** Underground Metro Station at
New Delhi
2. Type of Occupancy : Assembly building (D7as Per NBC Part IV 2005)
3. Type of Case : Renewal
4. Details of previous FSC : F6/DFS/MS/DMRC/2006/3432 dated 24.11.2006
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 19/09/2024
7. Name of the Inspecting Officer : Sh. Rajinder Atwal DO/CD &
Sh. Ravinder Singh ADO/CC
8. Name and designation of Officer
from the building side : Sh. Omkara & Sh. Ravinder (Fire officer)
9. Year of Construction : 2006
10. Applicant's letter No. :DMRC/O&M/FIRE/NOC/L3/2024/08 dated
22.08.2024

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	U/croft to PF 2 s/c @ 1200 mm each P/F to Con. 6 s/c, 4 s/c @ 2400 mm, 2 s/c @ 1200 mm, Con. To Gr. 7 s/c, 6 s/c @ 2600 mm, 1 s/c @ 1200 mm	U/croft to PF 2 s/c @ 1200 mm each P/F to Con. 6 s/c, 4 s/c @ 2400 mm, 2 s/c @ 1200 mm, Con. To Gr. 7 s/c, 6 s/c @ 2600 mm, 1 s/c @ 1200 mm	MR
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	U/croft to PF 2 s/c @ 1200 mm each P/F to Con. 6 s/c, 4 s/c @ 2400 mm, 2 s/c @ 1200 mm, Con. To Gr. 7 s/c, 6 s/c @ 2600 mm, 1 s/c @ 1200 mm	U/croft to PF 2 s/c @ 1200 mm each P/F to Con. 6 s/c, 4 s/c @ 2400 mm, 2 s/c @ 1200 mm, Con. To Gr. 7 s/c, 6 s/c @ 2600 mm, 1 s/c @ 1200 mm	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided in Fire man & Emg. s/c	MR
	2. Pressurization (fire man staircase)	Required	Provided	MR
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	5.0 m	5.0 m	MR
	F. Door size	N/A	N/A	N/A

3.	Compartmentation			
	1) Fire check door(fire man staircase)	Required	Provided	MR
	2) Sealing of electrical shafts/opening	Required	Provided	MR
	3) Fire rating of shaft door	Required	02 hrs. Provided	MR
	4) Fire curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR
4.	Smoke Management System			
	1) Basements	30 ACPH	Not in new operation room	N MR
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	100 Nos.	120 Nos.	MR
	2) Types	CO2 & Water gas	6KG ABC+9L water+4.5 KG Co ₂	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	27 Nos.	27 Nos.	MR
	2) Length of hose reel hose	30 mtr.	30.5 mtr.	MR
	3) Nozzle diameter	06 mm	06 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Smoke	Addressable multi sensor type and heat sensor	MR
	2) Location of main panel	Concourse	Station (C.R) Concourse	MR
	3) Location of repeater panel	Required	Fire man staircase (1 st Landing)	MR
	4) Alternate source of power	Required	UPS supply	MR
	5) Hooter's Location	Required	Floor wise	MR
8.	MOEFA	Required	Provided	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System.			
	1) Basement at some location	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm	MR
	2) Number of hydrants per floor	27 Nos.	27 Nos.	MR
	3) Hose box per floor	27 Nos.	6+20+1 = 27 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	01 no	01 no	MR
	2) Hose box	01 no	01 no	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850LPM	2850LPM	MR
	b) Head of main pump	90 mtr	90 mtr	MR
	c) Number of main pump	4 No.	4 No.	MR
	d) Jockey pump out put	180LPM	180LPM	MR
	e) Jockey pump head	90 m	90 m	MR
	f) Stand by pump output	Main pump is connected with DG set	Main pump is connected with DG set	MR
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual	Required	Provided	MR

	2) Terrace level			
	a) Discharge of pump	N/A	N/A	
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	2,00,000 ltr.	2 x 1,00,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: Clean. Agent flooding system for transformer & LT penal.			MR

The fire protection systems provided in metro station building only were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/DMRC/2006/3432 dated 24.11.2006, under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Signature]
23/9/24

Name: - Sh. Rajinder Attwal
Designation: - DO (CD)

Signature of the Inspecting Officer

[Signature]
23/9/24

Name: - Sh. Ravinder Singh
Designation :- ADO (CC)

[Signature]
C.F.O.

[Signature]
24/9/24

[Signature]
25/9/2024
Director

[Signature]
AD/CC