

c99

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2024/ 395

Dated :- 03/10/2024

FIRE SAFETY CERTIFICATE

Certified that the **Parkway Dx. Guest House** located at **8591, Main Qutab Road, Basti Arakashan, Pahar Ganj, New Delhi** comprised of Ground + 04 Upper floors, Ground floor (Reception + lobby + 01 office), 1st floor to 3rd floor (10 guest rooms at each floor), having fourth floor and terrace not in use as per affidavit dated 21.12.2019, total 30 guest rooms up to third floor, was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2021/251 dated 27/07/21. Now, the premises was re-inspected by the officer concerned of this department on 25/09/24 in the presence of Manager and found that the said guest house building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub Division-A-1 Ground floor (Reception + lobby + 01 office), 1st floor to 3rd floor (10 guest rooms at each floor), total 30 guest rooms & upto third floor only** and valid up to the period of three year from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 03/10/2024 ..at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, North MCD, Civic Centre, New Delhi : to kindly ensure the occupancy as detailed above and deviation if any .
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi id-no.2024082813224 dated 05/09/24.
3. The Manager, Parkway Dx. Guest House 8591, Main Qutab Road, Basti Arakashan, Pahar Ganj, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. **This FSC is valid for guest house up to third floor only.**
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape such as staircase , exits , corridor , etc shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any flammable material for interior decoration is prohibited.

138
INSPECTION REPORT

1. Name & address of the building
Parkway Dx. Guest House at 8591, Main Qutab Road, Basti Arakashan, Pahar Ganj, New Delhi.
2. Type of occupancy:-
Gr. + 04 Upper floors (Total 30 Guest rooms)
Ground floor (Reception + lobby + 01 office),
1st floor to 3rd floor (10 guest rooms at each floor),
4th floor and terrace floor sealed with brick wall
Not in use as per affidavit dated 21.12.2019
3. Type of case:-
Renewal
4. Details of previous FSC:-
No.F6/DFS/MS/GH/NDZ/2021/251 dated 27/07/21.
N/A
5. Fire safety directives No.-
25/09/24.
6. Date of inspection:-
Sh. Rajinder Atwal (DO/CD)
7. Name of the inspecting officer:-
Manager
8. Name & designation of officer
From the building side:-
2001
9. Year of construction:-
ID no 2024082813224 dated 05/09/24.
10. Applicant's letter No:-

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site PSS	Remarks MR/NMR
Old Case				
1.	Access to Building			
	1) Road width	N/A	N/A	N/A
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	01 No.	01 No. ✓	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	0.80 mtr.	1.35 Mtr. ✓	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR ✓
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	01 mtr.	01 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	12 Nos.	12 ✓	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR


	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors CO type	Required	Provided	MR
	2) Location of main panel	Ground	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	Ground	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump output	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5000 ltr.	5000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			MR

	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if agreed, we may renew the FSC issued vide letter no. F6/DFS/MS/GH/NDZ/2021/251 dated 27/07/21, renewal under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, reply letter is prepared and put up for kind perusal and signature please.

Signature of the Inspecting Officer



Name: - Rajinder Atwal
Designation: - DO (CD)

~~Dy. C.F.O. (CD)~~

~~Dir. P
26/09/24~~

~~C.F.O.
30/09/2024~~

~~Director
1/10/24~~

~~DO CP~~

As approved, F.T. letter is put up for signatures please.

~~Director~~

~~DO
27/10/24~~